ENERGY & SAFETY AUDIT REPORT

JUNE - 2021

J. D.Y. Patil Medical College, Hospital & Research Institute, Kolhapur.



Hospitals are institutions where the treatment of the sick and injured people is going on and usually function 24 hours per day, all year round. They usually consist of large buildings, and careful control of their internal climate is considered necessary. Substantial amount of heat is normally generated internally by the occupants and operating equipment. An effective cooling (and heating depending upon the external weather conditions.) and ventilation systems combined with good insulation of hospital building, usually reduce hospital's sensitivity to the outside weather. Hospitals also require standby electricity generators to ensure a continuous supply of power in emergencies and critical operations.

Generally, hospital building is designed for long-term use and, in practice, is often used for longer periods than its builders ever intended. The actual lifetime of building is normally over 60 years. During this period, the building is retrofitted and renovated many times. Reasons for this include the shorter life of technical equipment, the development of new types of equipment and health care facilities, new regulations, new energy-saving technologies and the ageing of the building itself.

When considering energy-efficiency in hospitals, it is important to keep in mind that it is not the end-use of energy alone, but also the need to control the indoor climate, that is one of the principal requirements. The indoor climatic requirements are determined by the hospital activities in the building. Once these are established, it is necessary to provide the required climate, ideally in the most economical way. Now a days, energy efficiency is increasingly becoming important requirement, but medical considerations remain the top priority in the hospitals.

The main source of energy used in this hospital is electrical energy. It is mainly used in this hospital for cooling/heating equipment, lighting, air compressors, water pumps, fans and ventilation. Other applications include laundry equipment; kitchen and canteen equipment; ovens and geysers and medical equipment including autoclaves, office facilities such as computers and photocopiers, utilities such as lifts, refrigerators, water coolers, etc.

Another source of energy is Compressed air can be divided into two main categories, namely medical air and technical air. Medical compressed air refers to the direct treatment and care of patients. Examples include breathing apparatus and surgical tools driven by the compressed air. The medical compressed air is subjected to very high standards for availability and quality. The technical compressed air is used for HVAC control systems, workshop applications or keeping containers under pressure.



INDEX

	Sr No.	Name of the Topic	age Number
	1	Major Electricity End users	03
,	2	Transformer-1 & 2	04
	3	Air conditioning Load	06
4	4	Substation Cabin	10
	5	Generators 1& 2	10
(5	Fire fighting cabin	10
,	ř.	Street lighting and Security cabin	11
8	1	Ground floor passage, MJPJY counters 1 & 2	12
9	ı	Case paper room ,ECG room, Medicine OPD	13
1	0	Surgery OPD, Orthopedic room	14
1	1	Physiotherapy room, Orthopedic cabin, Dressing room	15
1	2	Mr. Ajit Patil cabin, Dietician cabin, Dressing room	15
1	3	Operation Theater, Mother craft unit	16
1	4	Immunization, pediatrics, pediatrics demo room	17
1	5	ORT Center	17
1	6	Asst. Professor, Post natal clinic, Colposcopy	18
1	7	Professor & HOD(Obs & Gyn.), OPD, TMT Test	19
2	C	Dental OPD, M.S. Cabin, Sanjay sir Cabin	20
2	1	Casualty and Casualty ward	21
2:	2	Intupatient Room, CMO cabin, SWAB Test	22
2:	3	Antigen Test 1 & 2, TT room,	23
24	1	X- ray & Sonography, Panel room, CT scan, Console ro	oom 24
2.5	5	UPS room, X-ray room, Mammography	25



INDEX

Sr No.	Name of the Topic	Page Numbe
26	Central clinical Lab, Immunoassay Dept.	26
27	Cyto pathology	26
28	VITEK room, HOD room, Reporting room, FNAC	27
29	Serology 1 & 2, Housekeeping room	28
30	Bacteriology, Mycology, Inverter room, Reception	29
32	Blood bank, Reception, Medical officer room	30
33	Refreshment room, Aphaeresis room	30
34	Serology Lab, TTD room, Washing & Sterilization	31
35	Blood component storage	31
36	Office & Record room, Component preparation room	32
37	Blood collection room & Medical shop	32
38	ENT OPD, ENT HOD, ENT OPD2, ENT OPD3	33
39	ENT OPD4, ENT OPD5, ENTOPD6	34
40	Ortho OPD4 &5, Clinical Demo Room, optical shop	36
41	Medical shop, Time office	37
42	Gynac section, Gynac ward	38
43	Operation Theater section	41
44	OT passage, Operation Theater 1 & 2	42
45	Operation Theaters 3, 4, 5	43
46	Operation Theaters 6, 7, 8	44
47	Operation Theater 9,OT rooms, Counseling room	45
48	Pre operative room, OT Passage, HOD room, Store (2) 46
49	Bio medical room, Associate Professor room, Museum	



50	Central sterile room, Housekeeping store	48
	INDEX	
Sr No.	Name of the Topic	Page Numbe
51	Another side X-ray room, Seminar Room	48
52	Professor & HOD, X-ray(500 mA), X-ray(800mA)	49
53	X-ray(300mA), X-ray(800mA), other rooms	50
54	Medical record section, Second Floor	51
55	Passage, Male surgery ward, sister room	51
56	Doctor room, pantry, Treatment room, Toilet	52
57	Third ward	53
58	Second Floor medicine ward	54
59	SISU	55
60	Third floor ward, C wing, Psychiatric ward	57
61	ECT room, Demo room, Skin disease HOD room	58
62	Assistant Professor Dermatology	58
63	PUVA chamber, Asst, Prof. Pharmacology	59
64	Associate Professor, Pediatric chamber, Gynecology	59
65	Artist room, Pediatrics ward, ICU	60
66	Septic ICU, Mother feeding ward, Step down Room	61
67	ICU3, Clinical demo room, Doctor duty room, pantry	62
68	Treatment room, store, pulmonary lab, NICU Ward	63
69	Third floor ENT section	64
70	Third Floor, Nursing staff hostel	65
71	Fourth floor Corona ward	66
72	Ladies Hostel rooms	67



73	Fourth floor Nursing Boys Hostel, General ward	68
74	Fifth floor Intern Section	70
Sr No.	Name of the Topic	Page Number
75	Lift Room, Male, Female Resident Doctors Hostel	71
76	Medical Gas Unit, Main staircase Lighting	72
77	Laundry Section, Central store, Hospital canteen	73
78	Other Canteens, Workers shade	74
79	Energy Saving Suggestions	75



SUMMERY

Sr. No.	Floor Number	Total Load
Dr. D. Y	. Patil Hospital	
1	Ground Floor	851036 W
2	First Floor	3616110 W
3	Second Floor	32221 W
4	Third Floor	48297 W
5	Fourth Floor	25067 W
6	Fifth Floor	54355 W
	Total	4627086 W
Nursing	College	
6	Ground Floor	18025 W
7	First Floor	24140 W
	Total	42165 W



Major Electricity End-Users in Hospitals are as follow:

Air Conditioning System

Mainly split air conditioners are used here, and these Air Conditioners are consuming major share of the total electricity consumption. Air Conditioning and Ventilation system in hospital is required for:

- Maintaining the requisite indoor temperature, air distribution and humidity levels for thermal comfort.
- Maintaining indoor air quality, particularly in areas requiring prevention of infection

Building envelope design plays a very important role in the determination of Heat Ventilation and Air Conditioning capacity in the hospital.

Lighting

Lighting is a major electricity consumer next only to HVAC systems. Requirement of lights in a hospital varies widely depending upon the activity, time of day and the occupancy level. The complexity can be well understood from the simple fact that IS Code (NBC) 3646(edition 1992) recommends Illuminance level varying from one Lux for night lighting in some areas to 750 Lux in operation theaters for general requirements. At times special lights are used with illuminance of 10,000-50,000 Lux in operation theaters. (Lux is the unit to measure light intensity.)

Electrical Motors

Water is consumed in different sections of the hospitals for various requirements. In this hospital, electrical motors are used for various purposes like, water pumping systems, Compressed air system, various laundry equipments etc, may account for 5-15% of total electricity consumption and offer scope for reducing energy consumption.



Medical Hospital Campus.

Details of the transformers are as mentioned below:

Transformer No.1:

Manufacturer: Siddhi Vinayak Transformer Industries, Kakati, Belgaum.

Rated KVA: 500 KVA.

Parameter	High Voltage	Low Voltage
Volts	11000(Volts)	433 Volts
Current	26.25 Amperes	666.7 Amperes
Frequency	50 Hz	Oil Temp.: 31°c
Type of cooling	Oil Natural Air Natural	
Oil (Kg)	485 Kg.(550 Liters)	
Туре	Wound Transformer	

Transformer No.2:

Manufacturer: Static Electricals, Pune.

Rated KVA: 630 KVA.

Parameter	High Voltage	Low Voltage
Volts	11000(Volts)	433 Volts
Current	33.07 Amperes	840 Amperes
Frequency	50 Hz	Oil Temp.: 31°c
Type of cooling	f cooling Oil Natural Air Natura	
Volume of Oil	750 Liters	
Туре	e Wound Transformer	


Amount	KWH	MD
1488860		432
1389029		300
1398298		300
1537717		300
	1488860 1389029	1488860 114500 1389029 103730 1398298 104760



Average	14,22,795	105853	307
Total	1,84,96330	1376095	3948
Aug-2020	1350893	99845	275
	1387541	102970	275
Sept-2020	1382541	102410	275
Oct-2020		95910	305
Nov-2020	1322330		275
Dec-2020	1302229	95470	177
Jan-2021	1386397	102300	275
Feb-2021	1257381	91850	275
Mar-2021	1631715	119845	336
April-2021	1661399	125735	325

Average cost of Unit is Rs. 13.441235/-

Monthly Bill Amount





17	Spittituinology Of D	39	Split	$\overline{1}$
10	Ophthalmology OPD	40	Split	1
18	- Tall	41	Cassette	3
	Conference Hall	42	Cassette	3
	Conference Hall	43	Cassette	$\frac{3}{3}$
	Conference Hall	44	Cassette	$\frac{3}{3}$
	Conference Hall	45	Cassette	$\frac{3}{3}$
19	X-Ray Dept HOD Room	46	Split	
	X-Ray Dept HOD Room	47	Split	1.5
20	Main O.T	48		1.5
	Main O.T	49	Split	1.5
	Endocrinology	50	Split	1.5
	Septic O.T	51	Split	2
	Post O.T	52	Split	2
	Post O.T	53	Split	1.5
		33	Split	1.5
	O.T No 1	54	AHU Laminar	
60		74	Flow	8.5
	O.T No 2	55	AHU Laminar Flow	0.5
		- 55	AHU Laminar	8.5
	O.T No 3	56	Flow	0.5
			AHU Laminar	8.5
	O.T No 4	57	Flow	8.5
	O.T.N. 6		AHU Laminar	0.5
	O.T No 5	58	Flow	8.5
	O.T No 6		AHU Laminar	0.5
	0.1 No 6	59	Flow	9
	O.T No 7		AHU Laminar	
	0.1 110 /	60	Flow	8.5
	O.T No 8		AHU Laminar	
21	D.S.A Unit	61	Flow	8.5
	O.T Passage	62	Split	1.5
-	O.T Passage	63	Cassette	3
	O.T Passage	64	Cassette	3
	O.T Passage	65	Cassette	3
	Anesthesia	66	Cassette	3
22	2nd floor	67	Split	1.5
44				
	SICU	68	Ducted	8.5
	SICU	69	Ducted	11
	MICU	70	Ducted	8.5
-	MICU	71	Ducted	8.5
23	Medicine Ward	72	Split	1.5



	Medicine Ward	73	Split	1.
	Medicine Ward	74	Split	
2	4 Surgery Demo Room	75	Split	1
	Surgery Demo Room	76	Split	1.:
	5 Surgery Seminar Room	77	Split	
2	6 Medicine Seminar Room	94	Split	1.5
	Medicine Seminar Room	95	Split	
	Medicine Seminar Room	96	Split	1.5
2	7 NICU		Opiti	1.5
	PICU	78	Split	1.6
	PICU	79	Split	1.5
	Clinic Demo Room	80	Split	1.5
28	- 5) omatric Dept	81	0.000	1.5
	Psychiatric Dept	82	Split Split	1.5
29	4th Floor Lab Skill lab	83	Split	1.5
		84	Split	1.5
		85	Split	1.5
90 S		86	Split	1.5
		87	Split	1.5
		88	Split	1.5
		89	Split	1.5
	Research Lab HOD Cabin	90	Split	1.5
	Research Lab Covid-19	91	Split	2
	Research Lab	92	Split	1.5
	Research Lab	93	Split	110
	Research Lab	94	Split	
	Research Lab	95	Split	1
30	R.N.T.C.P		Split	-1-
		96	Split	1.5
		97	Split	1.5
		98	Split	1.5
31	M.R.I Room	99	Split	1.5
		100	Ducted	11
32	C.T Scan	101	Ducted	11
		102	Ducted	5.5
33	Console Rooms ,ETC	103	Ducted	5.5
34	Pathology	104	VRF	16
35	A. wing Skill Lab	105	VRF	26
	ang okin Lab	106	VRF	30
36	A Wing Conference D	107	VRF	30
37	A. Wing Conference Room	108	Cassette	3
	A. Wing Server Room	109	Split	1



			Total TR	439.5 T
		117	Split	2
45			Split	2
44	Gynac Conference Room	116		1.5
43	Gynac Pre Delivery Room	115	Split	
42	Gynac OT Room	114	VRF	16
41	Gynac OT	113	AHU Laminar Flow	8.5
	A. Wing Passage	112	Cassette	2
<u>39</u> 40	A. Wing Skill Lab Admin Block	111	Split	1
38	A. Wing Skill Lab In charge Room	110	Split	

O



1) Substation Cabin

Electrical Load	Wattage	Numbers	Total consumption (14)	
RoomNo.1: Panel C	abin	111111111111111111111111111111111111111	Total consumption(Watts)	Remark
Tube light	20 W	2	40	
Tube light	55 W	1	55	
Incandescent Bulb		3		
Room No.2: 320 KV		r	180	Phase Indicators
Tube light	20 W	1	20	
Tube light	55 W	1	20 55	
Tube light	45 W	1	45	
Room No.3: 500 KV		r	43	
Tube light	20 W	1	20	
Tube light	55 W	1		
Total		-	55	
) Generator Details:			470 W	

Generator 1 ▼

Manufacturer	M/s Kirloskar Oil
	Engines Limited.
KVA	320
KW	256 (0.8 PF)
Volts	415, 3 Phase, 50Hz
Amps	445.2 A
RPM	1500
Connection	Star
Tank capacity	850 Liter

Generator 2 ▼

Manufacturer	M/s Kirloskar Oil		
	Engines Limited.		
KVA	500		
KW	400 (0.8 PF)		
Volts	415, 3 Phase, 50Hz		
Amps	695.6 A		
RPM	1500		
Connection	Star		
Tank capacity	990 Liter		

i) V_{L-N} =234 V ii) V_{L-E} = 228 V iii) V_{N-E} = 2.1 V (Measured in Substation area)

3) Fire Fighting Cabin

Electrical Load	Wattage	Numbers	Tabl	
Tube lights	20 W	radilibers	Total consumption(Watts)	Remark
		2	40	
Motor-pump set	30,000 W	2	60,000	
Motor Pump set	7300 W	1	7300	
Other places:		_	7300	
Gardening motor pump	11000 W	1	11000	
Submersible pump		-	11000	
Total	7000 W	1	7000	
TOTAL			85340 W	



Some useful tips for substation maintenance:

Inspect substation fencing/ gate / lock/ signage/ damage.

- Inspect substation grounds weed / etc.
- Inspect outside lighting.
- Check earth connection are tight and in good condition.
- Inspection paintwork condition.
- Check for oil leaks.
- Inspect cable condition.
- Inspect paintwork condition.
- Keep area near by the transformer clean
- Maintain Logbook of substation maintenance.

Street lighting:

Electrical Load	Wattage	Numbers	Total consumption(Watts)	T
Halogen Lamp	50 W	1	50	Remark
LED Lamp	150 W	1		Substation
LED Lamp	250 W	3	150	Canteen back
LED Lamp	150 W	1	750	Canteen back
LED Lamp	400 W	70-2	15	Canteen back
LED Lamp		1	400	Canteen back
	350 W	2	700	Security Gate
LED Lamp	150 W	1	150	Security Gate
LED Lamp	250 W	2	500	Gate parking
LED Lamp	150 W	3	450	
LED Lamp	200 W	1	200	Gate parking
LED Lamp	200 W	2	400	Old store parking
LED Lamp	350 W	3	1050	Accident ward
LED Lamp	400 W	1		Temple area
Tube lights	20 W	22	400	Temple area
LED Lamp	250 W		440	College logo
Total	230 W	1	250	Near Dust Bin
Total			5905 W	

Security Cabin:

Electrical Load	Wattage	Numbers	Total consumption(Watts)	D- 1
Tube light	20 W	1	20	Remark
Ceiling Fan	80 W	1	80	
Total			100 W	

Ground floor passage and porch

Electrical Load	Wattage	Numbers	Total consumption(Watts)	I B .
Tube light	20 W	13	Tombamption (valls)	Remark
Ceiling Fan	80 W	5	260	9 in entrance porch
Light fittings	48 W	16	400	
Light fitting	15 W	81	768 1215	
Finger print scanner	5 W	2	10	
TV set	70 W	1	70	
Spot light	1W	3	70	
Water cooler	100 W	1	100	Show case
Total		•	2826 W	

MJPJY Counter 1:

Electrical Load	Wattage	Numbers	Total consumption(Watts)	D
Tube light	20 W	1	20	Remark
Ceiling Fan	80 W	1	80	
CPU + Display	175 W	3	525	
Scanner cum printer	700°W	2	1400	
Total			2025 W	

MJPJY Counter 2:

Electrical Load	Wattage	Numbers	Total consumption (NV	-
Tube light	20 W	2	Total consumption(Watts)	Remark
Ceiling Fan	80 W	1	80	
CPU + Display	175 W	7	1225	
Scanner cum printer	500 W	5	2500	
X-ray viewer	20 W	1	20	
Total			3865 W	

Cashier Room:

Electrical Load	Wattage	Numbers	Total consum (' (XX)	T
Tube light	55 W	2	tonouniprion (valls)	Remark
Tube light		2	110	
Call: E	20W	1	20	
Ceiling Fan	80 W	1	80	
CPU + Display	175 W	4	700	
Scanner cum printer				
stanter cam printer	700 W	4	2800	



Note counting machine	80 W	2	160	
Card swapping machine Total	10	2	20	
Total			3890 W	

Case paper room:

Electrical Load	Wattage	Numbers	Total comment (* (*)	
Tube light	20W	2	Total consumption(Watts)	Remark
Ceiling Fan	80 W	1	80	
Wall mounted fan	50 W	3	150	
CPU + Display	175 W	4	700	
Scanner cum printer	700 W	4	2800	
Total FCG Page			3770 W	

ECG Room:

Electrical Load	Wattage	Numbers	Total consumption (IV)	
Tube light	20W	2	Total consumption(Watts)	Remark
Ceiling Fan	80 W	1	80	
ECG Machine	24 W	1	24	
Total			144 W	

Medicine OPDs:

Electrical Load	Wattage	Numbers	Total consumption (NV	T
OPD I		1	Total consumption(Watts)	Remark
Tube light	20W	1	20	
Ceiling Fan	80 W	1	80	-
X-ray viewer	60 W	1	60	
OPD 2			00	160 W
Tube light	20W	1	20	
Ceiling Fan	80 W	1	80	-
X-ray viewer	24 W	1	24	
CPU + Display	175 W	1	175	
Printer	600 W	1	600	
OPD 3		-1	000	899
Tube light	20W	1	20	
Ceiling Fan	80 W	1	80	
X-ray viewer	24 W	1	24	
OPD 4			27	124 W
Tube light	20W	1	20	The state of the s
Ceiling Fan	80 W	1	80	
X-ray viewer	24 W	1	24	
Total			1307 W	124 W



Ajit Patil Cabin:

Wattage	Numbers	Total consumentia (IV)	
	6	- The man beautiful to all si	Remark
	1		
	2		
	1		
	1		
	15 W 80 W 175 W	15 W 6 80 W 1 175 W 2	15 W 6 90 80 W 1 80 175 W 2 175

Dietician Cabin:

Electrical Load	Wattage	Numbers	Total consumption (IV)	
Light fitting	15 W	2	Total consumption(Watts)	Remark
Tube light	20 W	2	40	
X-ray viewer	30 W	2	60	
Total			130 W	

Dressing Room

Wattage	Numbers	Total (Watta)	D 1
- 0	1	()	
The second second	1		Male Dressing Room
	1		<u></u>
	1		Female Dressing Room
		200	J
	Wattage 20 W 80 W 20 W 80 W	20 W 1 80 W 1 20 W 1	20 W 1 40 80 W 1 60 20 W 1 40

Minor Operation Theater:

Electrical Load	Wattage	Numbers	Total consumption(Watts)	D
Tube light	20 W	7	140	Remark
Operation Lamp	500 W	1	500	
Suction Machine	85 W	1	85	
Monitor	20 W	1	20	
Total			745 W	

Mother craft Unit:

Electrical Load	Wattage	Numbers	Total consumation	
Light fitting	15 W	4	Total consumption(Watts)	Remark
Light fittings	20 W	2	40	
Fan	80 W	2	160	
Total			260 W	

Immunization:

Electrical Load	Wattage	Numbers	Total acressed	
Tube light	20 W	2	- The samperon (watts)	Remark
Fan	80 W	1	40	
Pedestal Fan	50 W	1	80	5 E
CPU + Display	175 W	1	50	
Scanner cum printer	600 W	1	175	si .
Freezer	264 W	1	600	
X-ray viewer	60 W	2	264	
Total	00 W	2	120	1
Total			1329 W	

Pediatrics:

Electrical Load	Wattage	Numbers	Total comment:	
Tube light	20 W	2	Tombamphon (* atts)	Remark
Fan	80 W	1	40	
CPU + Display	175 W	1	80	
Scanner cum printer	700 W	1	175	
Fridge	100 W	1	700	
X-ray viewer	60 W	1	100	
Total	OU W	4	240	
- 5001			1335 W	-

Pediatrics Demo Room:

Electrical Load	Wattage	Numbers	Total	1
Light fitting	15 W	6	- visamperon (valls)	Remark
Fan	80 W	0	90	
Electronic Trade mill		6	480	
	700 W	1	700	
Auto traction unit	20 W	1	20	
Freezer	264 W	1		
Total	20117	<u>. </u>	264	
			1554 W	

ORT Center:

Electrical Load ORT center	Wattage	Numbers	Total consumption(Watts)	Remark
Tube Light	20 W	1	20	
Fan	80 W	1	20	
OPD 1		1	80	
Tube Light	20 W	1	20	

Total			832 W	
CPU + Display	175 W	1	175	
CDIT D: 1	17 W	1	17	
Weighing scale		1	80	
Fan	80 W	+1	20	Table 1 state
Tube Light	20 W	1	120	
OPD 3			113	
CPU + Display	175 W	1	175	
X –ray viewer	20 W	1	20	
Fan	80 W	1	80	
Tube Light	20 W	1	20	
OPD 2			1.20	
X -ray viewer	20 W	1	.20	
Stadiometer	25 W	1	25	
Fan	80 W	1	80	

Assistant Professor (Obs & Gynac)

Electrical Load	Wattage	Numbers	Total consumption(Watts)	D.
Tube light	20 W	2	40	Remark
Fan	80 W	1	80	
CPU + Display	175 W	1	175	14
X-ray viewer	60 W	4	240	
Total			535 W	

Post Natal Clinic:

Electrical Load	Wattage	Numbers	Total consumption(Watts)	
Tube light	20 W	1	20	Remark
Fan	80 W	1	80	
X-ray viewer	60 W	1	60	
Total			160 W	

Colposcopy:

Electrical Load	Wattage	Numbers	Total consumit	
Light fittings	15 W	2	- susumption (watts)	Remark
Fan	80 W	1	30	CHILD TO THE PARTY OF THE PARTY
CPU + Display		1	80	
	175 W	1	175	
Scanner cum printer	600 W	1	600	
Sterilizer Unit	1000 W	1	1000	
colposcope	46 W	1		
Total	10 11	1	46	
- Otter			1931 W	

Professor and HOD (Obs & Gynac)

Electrical Load	Wattage	Numbers	Total agency	
Tube light	20 W	2	Total consumption(Watts)	Remark
Fan	80 W	1	80	
X-ray viewer	60 W	1	60	
Total			180 W	

OPD

Electrical Load	Wattage	Numbers	Total	
Tube Light	20 W	1	Townstamption (vv atts)	Remark
Fan	80 W	1	20	
LED Bulb	10 W	1	80	
Faetal Doppler	5 W	1	10	
Total	3 W	1	5	
Total			115 W	

OPD (Room no. 3)

Electrical Load	Wattage	Numbers	Total consumption (IV)	
Light fittings	15 W	10	- Tomouniperoni vvalls)	Remark
Light fittings	1 W	5	150	
Fan	80 W	3	3	
TV set	80 W	1	240	
TV set	70 W	1	80	
Set top box		1	70	
Total	17 W	1	17	
Total			562 W	

TMT Test:

Electrical Load	Wattage	Numbers	Total agreement	
Light fitting	15 W	1	and the state of t	Remark
Tube light		4	60	
	20 W	. 1	20	
Trade mill	230W	1	230	
CPU + Display	175 W	3		
Scanner cum printer	600 W	2	525	
Total	000 W	2	1200	
iviai			2035 W	

Dental OPD (16)

Electrical Load	Wattage	Numbers	Total	
Light fitting	15 W	17	- Tomounipully walls	Remark
Ceiling Fan	80	17	255	
		4	320	
X – ray machine	900 W	1	900	
Dental chair	800 W	2	1600	
Air purifier	50 W	1		
Ultrasonic Cleaner	70 W	1	50	S 60
UV cleaner		1	70	
	30 W	1	30	
Total			3225 W	

MS Cabin (18)

Electrical Load	Wattage	Numbers	Total	
Light fitting	15 W	12	Tombull Walls)	Remark
Light fitting	10 W	2	180	
Ceiling Fan	80	3	20	Washroom
TV set	370 W	1	240	
Set top box	17 W	1	370	
Corona guard	30 W	1	17	Set top box
CPU + Display	146 W	1	30	Too don
CPU + Display	175 W	1	146	4
Scanner + printer	2.00		175	
Microwave oven	700 W	1 ,	700	
Y round	1400	1	1400	17
X –ray viewer	15	1	15	
l'otal			3293 W	

Hon. Sanjay sir cabin:

Electrical Load	Wattage	Numbers	Total	1
Light fitting	36 W	7	The state of the s	Remark
Light fitting	10 W	2	252	
Light fitting	15 W	1	20	Washroom
Tube light	20W	1	15	
Tube light	12 W	1	20	
Ceiling Fan	80	1	12	
TV set	370 W	4	320	
Set top box	17 W	1	370	
Pedestal fan	50 W	1	17	
Steam Iron	1500 W	1	50	
CPU + Display	175 W	1	1500	
	11/3 W	1	175	



Emergency ventilator	300 W	1	300	
Microwave oven	1400	1	1400	
Fridge	100 W	1	100	
Exhaust fan	30 W	2	60	
Fan Fotal	50W	1	50	
Casualty:			4661 W	

Electrical Load	Wattage	Numbers	Total	
Rest Room		1 (dillibers	Total consumption(Watts)	Remark
Light fitting	15 W	8	120	
Tube light	20W	2	120	
Ceiling Fan	80 W	2	40	
Changing Room	100 11	12	160	
Light fitting	15 W	9		
Ceiling Fan	80 W	1,	135	3 in passage
Operation Theater and	I abor Poor	1	80	o in pussage
Light fitting	15 W	7		
Fan	50 W	3	45	
Operation Theater	130 W	1	50	
Light fitting	15 11/		E.J.	
ight fitting	15 W	4	60	
Radiant warmer	36 W	4	144	
Suction machine	600 W	1	600	
peration Theater	85 W	1	85	
ight fitting				
nesthesia workstation	36 W	4	144	
uction and Li	1840 W	1	1840	
uction machines	85W	-	255	
T LED lamps otal	40 W		40	
	rd:		3798 W	

Electrical Load	Wattage	Numbers	Total	
Light fitting	36 W	24	+ consumption (valts)	Remark
Light fitting	10 W	47	804	
Ceiling Fan	80	20	470	
Patient Monitors	90 W	7	1600	
Patient monitor	150 W	1	630	
Ventilators	300W	5	150	
X -ray machine	900W	1	1500	
Water cooler	100 W	1	900	
LED lamp	40 W	1 1 1	100	
Total	TO W	14	560	
			6774 W	

Intupatient Room:

Electrical Load	Wattage	Numbers	Total	,
Light fitting	36 W	4	Total consumption(Watts)	Remark
Ceiling fan	80 W	1	80	
Mini Freezer	130 W	1	130	
Total			354 W	

Passage and Lobby:

Electrical Load	Wattage	Numbers	Total	
Light fitting	15 W	5	- valis	Remark
Light fitting	10 W	2	75	Outside
Pedestal Fan	50	1	50	
CPU + Display	175 W	1	175	
Printer	600 W	1	600	
Total		-	920 W	

CMO Cabin:

Electrical Load	Wattage	Numbers	Total commune the care	
Light fitting	10 W	3	Total consumption(Watts)	Remark
Ceiling fan	80 W	1	80	
X -ray viewer	60 W	1	60	
Total			284 W	

Swab Test:

Electrical Load	Wattage	Numbers	Total	
Light fitting	200 W	2	- Tombumpuoni vy allsi	Remark
Tube light	20 W	2	400	
Pedestal fan	50 W	1	40	
CPU + Display	175 W	2	50	
Printer	600 W	1	350	
Total		1	600	
			1440 W	

Antigen Test 1:

Electrical Load	Wattage	Numbers	Total	
Light fitting	10 W	2	the consumption (watts)	Remark
Tube light	20 W	1	20	
Pedestal fan	50 W	:	20	
Laptop		1	50	
Printer	100 W	1	100	
· ·	700 W	1	700	
Total			890 W	

Antigen Test 2:

Electrical Load	Wattage	Numbers	Total	
Light fitting	10 W	2	(Stik M. Mondinberro	Remark
Tube light	20 W	1	20	-
Pedestal fan	50 W	1	20	
Laptop		1	50	
Printer	100 W	1	100	
	700 W	1	700	-
Fridge	150W	1	150	
Total				
IT Room:			1040 W	

Electrical Load	Wattage	Numbers	Total	
Light fitting	15 W	R	the consumption (watts)	Remark
CPU + Display	175 W	2	144	
Printer	600 W	2	350	
Printer		1	600	
Total	700 W	1	700	
Total			1794 W	

Toilet:

Total consumption(Watts) Remark
1

Passage

Electrical Load	Wattage	Numbers	Total consum (: and	
Light fitting	10 W	49	Total consumption(Watts)	Remark
Light fitting Total	1 W	12	12	
Total			502 W	



X -ray and Sonography:

Electrical Load	Wattage	Numbers	Total consumntia (XX	
THE CIPCH Pane	130 W	2	Total consumption(Watts)	Remark
Tube Light Pane CPU + Display	175 W	2	350	
Printer	600 W	1		
TV set	70 W	1	600	
Set to box	17 W	1	70	
Pedestal Fan	50 W	1	17	
Total	30 W	1	50	
			1087 W	

Electrical Panel Room:

Electrical Load Tube Light 120 KVA inverter	Wattage 20 W	Numbers 1	Total consumption(Watts)	Remark
120 KVA inverter	3960 W	3960 W 1 396	3960	With 30 Batteries of 100 AH
Total			3980	Capacity.

CT Scan Center:

Electrical Load Light fitting CT scanning machine Total	15 W	Numbers 9	Total consumption(Watts) 135 45000	Remark
			45135 W	

Console Room:

CPU + Display	Wattage 15 W 175 W	Numbers 10	150	Remark
Printer	600 W	1	1225 600	
Printer Total	700 W	1	700	
· otal	-		2675 W	

MRI Scanner Room:

Electrical Load	Wattage	Numbers	Total	
Light fittings	15 W	12	consumption (Waffe)	Remark
CT Scanner	2500 W	12	180	
Total	2300 W	1	2500	
. Otal			2680 W	

Electrical Load	Wattage	Numbers	Total congress (
Light fittings	15 W	1	Total consumption(Watts)	Remark
20 KVA inverter	2574	1	2574	100
Total		-		
X -ray Room / Sto			2589 W	

X -ray Room / Store

Electrical Load	Wattage	Numbers	Total consumption(Watts)	
Light fittings	11 W	8	ocal consumption(Watts)	Remark
Fridge	125 W	1	125	
Total		•	213 W	

Neighboring Room

Electrical Load	Wattage	Numbers	Total	
Light Bulbs	10 W	5	(Silk M Mondampung Marks)	Remark
X -ray viewer	50 W	1	30	
CPU + Display	175	2	50	
Total	175	3	525	
Iammography Ro			625 W	

Electrical Load Light Bulbs Mammography machine Total	110 111	Numbers 4	Total consumption(Watts) 40 3000	Remark
Sonography	Machine		3040 W	

Electrical Load	Wattage	Numbers	Total consumit
Light Bulbs	10 W	11	Total consumption(Watts) Remark
Pedestal Fan	50 W	1	50
Sonography Machine Total	400 W	2	800
· otta			960 W

Central Clinical Laboratory

Electrical Load	Wattage	Numbers	Total	-
Hematology and Co	pagulation C	ahin	Total consumption(Watts)	Remark
Light Hilling	15 W	6	90	
Cell counter	575 W	1	575	
Cell counter	110 W	1	110	Five part
HP ink tank printer	10 W	i	10	Three par
CPU +Display	175	1	175	
Biochemistry Labora	atory	•	173	
Light fitting	15 W	6	90	
Ceiling Fan	50 W	1	50	150.4 (0.00)
Siemens Rapid Lab	80 W	1	80	
Mispa nano plus	1300 W	1		
CPU +Display	175	1	1300	
otal		1	175	
			2480 W	

Immunoassay Department:

Electrical Load	Wattage	Numbers	Total	
Light fittings	15 W	6	Total consumption(Watts)	Remark
Ceiling Fan	50 W	1		
Adira centaur XP	2000 W	1	50	
Remi Centrifuge	660 W	1	2000	
CPU +Display	175 W	1	660	
Γotal		1	175	
			2975 W	

Cyto-pathology

Electrical Load	Wattage	Numbers	Total	
Light fittings	15 W	6	Total consumption(Watts)	Remark
Biopsy Machine	3200 W	1		
Coomb Tester	300 W	1	3200 300	
Total			3590 W	

VITEK Room:

Electrical Load	Wattage	Numbers	Total assessment	·
Light fittings	15 W	6	the consumption (watts)	Remark
Ceiling Fan	50 W	1	90	
BD BROTOREXAP	690 W	1	50	
Vitek 2 compact		l .	600	
CPU + Display	920 W	1	920	
Duint Display	175 W	1	175	
Printer Total	700 W	1	700	
rotar			2535 W	

HOD Room:

Electrical Load	Wattage	Numbers	Total	
Light fittings	15 W	6	the consumption (Watte)	Remark
Ceiling Fan	50 W	1	90	
Fridge	125 W	2	50	
Water cooler	120 W	1	250	
CPU + Display	175 W	2	120	
Total	175 VV	2	175	
			625 W	

Reporting Room:

Electrical Load	Wattage	Numbers	Total	-
Light fittings	15 W	6	the state of the s	Remark
Ceiling Fan	50 W	1	90	
Meltroscope	58 W	1	50	
CPU + Display	175 W		58	
Total	173 W	1	175	
- Otta			373 W	
FNAC:				

Electrical Load	Wattage	Numbers	Total congress of	
Light fittings	15 W	4	Total consumption(Watts)	Remark
Ceiling Fan Total	50 W	1	50	
Total			110 W	

Housekeeping Room:

Electrical Load	Wattage	Numbers	Total	
Housekeeping Re	oom	1. Tallibers	Total consumption(Watts)	Remark
Tube light	20 W	2	A	
Sample Room		2	40	
Light fitting	15 W	5		
Ceilscoragy:	50 W	1	75	
Cleaning Room	30 11	1	50	
Light fitting	15 W	1		
Ceiling Fan	80 W	6	90	
Fan	75 W	2	160	
Autoclave	2000 W	2	150	
Autoclave	1000 W	1	2000	
Passage	1000 W	1	1000	
ight fitting	15 117			-
Total	15 W	14	210	
			3775 W	

Serology 1:

Electrical Load	Wattage	Numbers	Total	
Light fittings	15 W	5	the consumption (Watte)	Remark
Ceiling Fan	80 W	2	13	
Deep freezer	5000 W	1	160	
Incubator	1000W	1	5000	
Rapid lab		1	1000	
CRP Tester	80 W	1	80	
CRP Tester	80 W	1	80	
	230 W	1	230	
CPU +Display	175 W	1	175	
Centrifuge	138 W	1	138	11.00
Jniplus 600	40 W	1		
otal			40	
Serology2:			6978 W	

Electrical Load	Wattage	Numbers	Total	
Light fittings	15 W	6	the walter	Remark
Ceiling Fan	80 W	2	90	
Fridge	110 W	1	160	
Incubator		1	110	
Bacteriological	1000 W	1	1000	
incubator	750	1	750	
Total				
			2110 W	

Bacteriology:

Electrical Load	Wattage	Numbers	Total constant	÷
Light fittings	15 W	6	(5118 M Honding and	Remark
Ceiling Fan	80 W	0	90	4.
Laminar air flow	The second secon	2	160	
	500 W	1	500	
Incubator	1000 W	1		
Total			1000	
			1750 W	

Mycology:

Electrical Load	Wattage	Numbers	Total comme	
Light fittings	15 W	6	(atte M Mondampunding	Remark
Ceiling Fan	80 W	2	90	
Fridge	125 W	1	160	7
Incubator		1	125	-
Electric microscope	1000 W	1	1000	
Discource inicroscope	57 W	5	285	
Blower	700 W	1	The state of the s	
l'otal	1	1	700	-
			2360 W	

Inverter Room:

5 KVA Inverter 6 KVA Inverter Total	1386 W	Numbers 1	1386 739	Remark 10 X 105AH 16 X 35 AH
---	--------	-----------	-------------	------------------------------------

Reception Area:

Electrical Load	Wattage	Numbers	Total	
Light fittings	15 W	9	tonsumption (Watte)	Remark
CPU + Display	175 W	1	133	a deal
Printer	600 W	-	175	
Photo Copier		1	600	
Photo Copiei	2760 W	1	2760	
Photo Copier	1012 W	1	1012	2
Sample Collection	Area:		1012	1
Light fittings	15 W	6		
Ceiling Fan	50 W	0	90	
Total	30 W	1	50	
			4822 W	3



Blood Bank Reception:

Electrical Load Light fitting	Wattage 10 W	Numbers	Total consumption(Watts)	Remark
Shoe Cover Wrapper Total	1300 W	1	70 1300	Kemark
Medical officer'	s Room		1370 W	

Electrical Load	Wattage	Numbers	Total	T. No.
LED Tube	54	4	(attention watte)	Remark
Ceiling Fan	80 W	1	210	
LED fitting	72 W	2	80	
Total	72 W	2	144	
			440 W	

Passage:

Electrical Load LED Tube LED fitting	Wattage 54 W 22 W	Numbers 4 5	Total consumption(Watts) 216 100	Remark
Total			316 W	

Refreshment Room:

Electrical Load	Wattage	Numbers	Total consumption(Watts)	
Light fitting	72 W	2	144 W	Remark
				(2)

Aphaeresis Room:

Electrical Load Light fitting Cobe spectra Total	Wattage 72 W 920 W	Numbers 4 1	Total consumption(Watts) 288 920 1208 W	Remark
--	--------------------------	-------------------	---	--------



Serology Lab:

Electrical Load LED Tube	Wattage	Numbers	Total agreement	
	72 W	2	(stie Walter	Remark
CPU + Display	175	1	144	
Fridge	100 W	1	175	
Card centrifuge		1	100	-
Cartridge warmer	1150W	1	1150	
Tube damer	600 W	1	600	
Tube sealer	1000 W	1		
Binocular microscope	58 W	1	1000	
Blood Centrifuge	138 W	1	58	
reezer	1.00	1	138	
otal	150 W	1	150	
TTD Testing:			3515 W	

Electrical Load	Wattage	Numbers	Total	
LED Tube	72 W	2	+ Consumption (Watte)	Remark
Tube light	20 W	1	144	
CPU + Display	175	1	20	
Printer		1	175	
Fridge	70 W	1	70	7
	150 W	1	150	
Incubator	1500 W	1	1500	1
Centrifuge	150 W	1		
Elisa Washer	240 W	2	150	
Total	210 W	2	480	-
Washing and s			2689 W	

Washing and sterilization

Electrical Load LED Tube fittings Exhaust Fan		Numbers 2	Total consumption(Watts)	Remark
Hot air oven	35 W 1500 W	1	35	
Autoclave Total	1000 W	1	1500 1000	
			2679 W	

Blood Component Storage:

ge Numbers	Total consumption (13)
2	Total consumption(Watts) Rem
2	40
/ 1	3200
7 1	2000
1	2000
	7 1

Deep freezer	2000 W 1	2000	-27
Platelet agitator Total	500 W 1	500	
Office and Re	cord Room:	9884 W	

Electrical Load LED Tube fittings	Wattage	Numbers	Total consumusi	
Tube fittings	72 W	4	Total consumption(Watts) 288	Remark
Hematology analyzer	180 W	1	180	
Coagulometer	690 W	1		
Digital Ph Meter	15 W	1	690	
Total		1	15	
Component Prep			1172 W	

Electrical Load	Wattage	Numbers	Total	
LED Tube fitting	72 W	6	Total consumption(Watts)	Remark
Laminar air flow	500 W	1		
Platelet agitator	500 W	1	500	
Refrigerated centrifuge	1955 W	1	500	
Plasma bath		1	1955	
Cryo bath	1100 W	1	1100	
Total	1600 W	1	1600	
			6087 W	

Blood Collection Room:

Electrical Load LED Tube fitting	Wattage	Numbers	Total consumption(Watts)	-
Donor station	72 W	4	288	Remark
Blood bank D. C.	120 W	3	360	
Blood bank Refrigerator Fridge	2000 W	1	2000	
Total	150 W	1	150	
			2798 W	

Ground Floor Medical stores Lobby:

Electrical Load Tube Light Ceiling fan Total	Wattage 20 W 80 W	Numbers 11 3	Total consumption(Watts) 220 240 460 W	Remark
--	-------------------------	--------------	--	--------

ENT OPD:

Electrical Load	Wattage	Numbers	Tatal
LED Tube fitting	6 W	4	Remissing Consumption (Waffs) Remission
Audiometry equipment	25 W	1	24
Scanner + printer	700 W	1	25
Laptop		1	700
Impedance audio meter	100 W	1	100
Total	16 W	1	16
			865 W

ENT HOD / OPD1

Electrical Load	Wattage	Numbers	Total	
LED Tube fitting	6 W	1	the state of the s	Remark
Ceiling Fan	80 W	1	24	
X- ray viewer	36 W	1	80	
CPU + Display	175	1	36	
Printer		1	175	
Bull lamp	600 W	1	600	
Total	18 W	1	18	
rotai			933 W	

ENT OPD 2:

Electrical Load	Wattage	Numbers	Total	3.5
Tube Light	20 W	2	- Watte	Remark
Ceiling Fan	80 W	1	40	- contain
X- ray viewer	36 W	1	80	
CPU + Display		1	36	1.
Pull	175	1	175	
Bull lamp	18 W	1	18	
l'otal			349 W	

ENT OPD 3:

Electrical Load	Wattage	Numbers	Total age	
Light fitting	6 W	4	the consumption (Wafte)	Remark
Ceiling Fan	80 W	1	24	
X- ray viewer	36 W	i	80	
Suction machine	85 W	1	36	
Bulls lamp	18 W	3	85 54	111
l'otal			279 W	

ENT OPD 4:

Electrical Load	Wattage	Numbers	Total	
Light fitting	6 W	4	tonsumption (Wafte)	Remark
Ceiling Fan	80 W	1	24	
X- ray viewer	36 W	1	80	
Fridge	125 W	1	36	
Sterilizer		1	125	
Microscope	1000 W	1	1000	
TV set	210 W	1	210	
	30 W	1	300	
Scanner + Printer	700 W	1	700	1.345
Light source	200 W	3	600	
Suction machine	85 W	1		
Total		1	85	
			3160 W	

ENT OPD 5:

Electrical Load	Wattage	Numbers	T.	
Light fitting	6 W		- Consumption (Wafte)	Remark
Ceiling Fan	80 W	6	36	Kemari
X- ray viewer		1	80	
Projector	36 W	1	36	
Printer Printer	700 W	1	700	-
	600 W	1	600	
TV set	100 W	1		
CPU +Display	175	1	100	
Scanner + Printer	700 W	1	175	
Total	700 W	1	700	
			2427 W	

ENT OPD 6:

Electrical Load		Numbers	Total consumption
Light fitting	6 W	4	Total consumption(Watts) Remark
Ceiling Fan	80 W	1	24
Laptop	100 W	1	80
Total		-	100
	-		204 W

Optho OPD 1:

Electrical Load	Wattage	Numbers	Total	
Light fitting	6 W	6	(atte)	Remark
Ceiling Fan	80 W	1	30	- Commun
X- ray viewer	36 W	1	80	
Vision drum		1	36	
Near vision drum	10 W	1	10	
TV VISION drum	5 W	1	5	
TV set	85 W	1	0.5	
Keratometer	100 W	1	85	
Slit lamp	30 W	1	100	
Surgical microscope		1	30	
Total	50 W	1	50	
· Ottal			432 W	

Optho OPD 2:

Electrical Load	Wattage	Numbers	Total	
Light fitting	6 W	2	tonsumption(Waffe)	Remark
Ceiling Fan	80 W	2	12	remain
Vision drum		1	80	
Near vision drum	10 W	1	10	
COLL VISION drum	5 W	1	5	
CPU + Display	175 W	1	175	
Scanner + printer	700 W	1	175	
Slit lamp		1	700	
Perimeter	30 W	1	30	
Total	40 W	1	40	
Total	-		1052 W	

Optho OPD 3:

Electrical Load	Wattage	Numbers	Total	
Light fitting	6 W	2	the state of the s	Remark
Ceiling Fan	80 W	2	12	rectifeli
Vision drum		1	80	
Near vision drum	10 W	1	10	17
CDI 1 Di	5 W	1	5	
CPU + Display	175 W	1	176	
Scanner + printer	700 W	1	175	
Keratometer superkms6	5 W	1	700	
enso-meter		1	5	
l'otal	25 W	1	25	
I a fu			1012 W	

Optho OPD 4:

Light fitting	Wattage 6 W	Numbers 2	Total consumption(Watts)	Remark
Ceiling Fan	80 W	1	80	
Specular microscope CPU + Display		1	100	
Scanner + printer	175 W 700 W	1	175	
Total	700 W	1	700	-
			1067 W	

Optho OPD5:

Electrical Load	Wattage	Numbers	Total	
Light fitting	6 W	2	Total consumption(Watts)	Remar
Ceiling Fan	80 W	1	12	
Fridge	125 W	1	80	
Slit-meter		1	125	
Total	30 W	1	30	
2000			247 W	

Clinical Demo Room:

Electrical Load Light fitting	Wattage	Numbers	Total consumption(Watts)	
W-11	15 W	6	90	Remark
Wall mounted Fan	50 W	2	100	100000000000000000000000000000000000000
X- ray viewer Total	36 W	1	36	
Total			226 W	

Optical Shop:

Electrical Load	Wattage	Numbers	Total	
Light fitting	6 W	2	Total consumption(Watts)	Remark
Wall Fan	50 W	1	12	
Tube light	14 W	3	50	
Total		-	42	
			104 W	

Medical Shop:

Electrical Load Light fitting	Wattage	Numbers	Total	
Tub- U. 1	15 W	16	Total consumption(Watts) 240	Remark
Tube lights	20 W	13	60	
Wall Fan	50 W	1	50	
CPU +Display	175 W	4		ella se
Printer	70 W	1	700	
Fridge	200 117	1	70	
Note counting machine	555 W	1	200	
Total	333 **	1	555	
			1875 W	

Time Office:

Electrical Load	Wattag	e Number	re Total	111	
Passage			13 Total consun	ption(Watts)	Remark
Tube lights	20 W	10		401	
Ceiling Fans	80 W	4	200	4/14	
Finger print scanner	5 W	111	120	74,44	
Cabin Number 1:		111	55		
Tube lights	20 W	1		1	
CPU +Display	175 W		20		
Cabin Number 2:	11/3 44	1	175		
Tube lights	20 W	Ta			
Wall Fan		2	40		
Ceiling Fans	50 W	1	50		
CPU +Display	80 W	1	80		
Printer	175 W	2	350		
Printer	1058 W	1	1058		
Cabin Number 3:	600 W	1	600		
Tube lights					
Ceiling Fans	20 W	1	20	100	
CET 1	80 W	1	80		
CFL lamp	80 W	1	80		
Cabin Number 4:			00		
CFL lamp	80 W	2	160		
Tube lights	00 -	2	40		
otal		-	3218 W		

First Floor:

First Floor Passage:

Electrical Load	Wattage	Numbers	Total	
Light fitting	15 W	10	the consumption (Wafte)	Remark
Light fitting	36 W	15	130	
Tube lights	20 W	13	540	
CFL light	36 W	4	80	
Water cooler		1	36	
Total	100 W	1	100	
. Ottal		- "	906 W	

Gynac Section:

Electrical Load tube lights	Wattage 20 W	Numbers 12	Total consumption(Watts) 240 W	Remark
-----------------------------	-----------------	---------------	--------------------------------	--------

General Ward:

Electrical Load General ward	Wattag	e Number	Total consumi	
Light fin:		•	S Total consumption(Watts)	Remark
Light fitting	15 W	12	180	
Light fitting	6 W	45	270	
Tube lights	20 W	36		
Ceiling fan	80 W	24	720	
Gynac Museum		124	1920	
Tube lights	20 W	12		
Ceiling fan	90 W	2	40	
Nursing Superintend	lent	1	80	
lube lights	20 W	1.		
Ceiling fan	80 W	.1	20	
Professor Room	00 W	1	80	
Tube lights	20 111			
Ceiling fan	20 W	1	20	
CFL Bulb	80 W	1	80	
Associate professor R	10 W		10	
ube lights				
eiling fan	20 W	1	20	per une construction of the construction of th
FL Bulb	80 W	1	80	
cyser	10 W	2	20	
	2000 W		2000	
ssociate professor R	oom		2000	6.00
ube lights	20 W	1	20	
eiling fan	80 W	1		
			30	

CFL Bulb				
Assistant P. C.	10	W	2 20	
Assistant Professo	r		20	
Tube lights	20 1	W	1 20	
Ceiling fan	80 7		1 80	
CFL Bulb	10 \		2 20	
Departmental Rese	earch Lab.		20	
Tube lights	20 V	V	20	
Ceiling fan	80 V			100 mg (100 mg)
CFL Bulb	10 W			
Library			20	
Tube lights				236
Ceiling fan	20 W	2	40	
CFL Bulb	80 W		80	
CDIT D: 1	10 W		10	
CPU +Display	175 V	V 1	175	
Laboratory			1/3	
Tube lights	20 W	2	40	
Ceiling fan	80 W	1	80	
CFL Bulb	10 W	1	10	
Professor and HOD I	Room		10	
Tube lights	20 W	3	100	
Ceiling fan	80 W	$\frac{1}{1}$	60	
CFL Bulb	10 W	$\frac{1}{3}$	80	
TV set	80 W	$\frac{3}{1}$	30	
Set top box	17 W	$\frac{1}{1}$	80	
Pediatric Doctor			17	
Tube lights	20 W	1		
Ceiling fan	80 W	$\frac{1}{1}$	20	
CFL Bulb	10 W	2	80	
20 KVA Inverter	1782 W		20	5694 W
Ladies washroom:	1702 W	1	1782	3912
tube lights	55 W	12		3912
LED Bulb	10 W	3	165	
Safety labor Room	10 W	1	10	
Tube lights	20 11	7		
Ceiling fan	20 W 80 W	2	40	
CFL Bulb		1	80	
Seminar Room	10 W	11	10	
Ceiling fan	100 111			
Light fitting	80 W	6	480	
TV set	15 W	12	180	
Hysteroscopy Room	330 W	1	330	
Light fitting	726 17:			
indoscope	36 W	4	144	
	460 W	1		
Endoscope light source	120 W	1	460	

Γ						
Display Unit	69 V	V	1		147	£3
Combi box	750		$\frac{1}{1}$	69	5 2	
Eclempsia	1,30	1	1	1		
Light fitting	36 W	1	2			
Ceiling fan	50 W		2	72	12-11	
Patient monitor	90 W			100		
Syringe pump	10 10	-	1	180		
Sonography Room:	10 VV		2	20		
Tube light fitting	18 W		4			
Ceiling fan	80 W	-	4	72		
Sonography Machin	e 75 W		1	80	177	
LICU	175 4			75		
light fitting	15 W					
light fitting	36 w	- 6	3	90		
Patient monitor	90 W	7		252		
Ceiling fan	50 W	6	State of the state	540		
Defibrillator	70 W	6		300		
Syringe pump	10 W	$\frac{1}{6}$		70		
Scrub Station	110 W	6		60		-
Light fitting	6 W	1.				
Ceiling fan	00 111	3		18		
Gynac Operation Th	OU W	1		80		
Light fitting						
Light fitting	6 W	4		24		D
Light fitting	6 W	5		30		Passage
Light fitting	36 W	3		108		Preparation
Intensive care warmer	6 W	5		30	-	operation
Suction machine		2		1200		theater
OT Lamps	85 W	1		85	1.00	
Anesthesia workstation	40 W	1		40		
Defibrillator		1		1840		-
Intensive care warmer	70 W	1		70		-
Light fitting	600 W	2	E- 10-10	1200		
Labor Room OT	6 W	6		36		
Light fitting						Student view
Light fitting	6 W	10		60		т
Ceiling fan	36 W	4		144		
Pedestal Lights	50 W	4		200		
Meditin warmer	50 W	6		300		
Weighing 1:	1000 W	2		2000		
Weighing machines Labor Room:	57 W	5		285		
ight fitting	-					
ight fitting	36 W	6		216		
Ceiling fan	6 W	4		24	377	
HS Monitors	50 W	3		150	**I(i)	
270 IVIONITORS	50 W	5		AUU		

<u></u>

Patient monitor	90 W	11		And the second
Doctors Duty Roo	m.	1	90	
Light fitting	6 W	4		
Ceiling fan	80 W		24	
Pantry	1 80 W	1	80	
Light fitting	6 W	75	Total	
Ceiling fan	80 W	2	12	
Doctors Lounge		1	80	
Light fitting	6 W	16		
Ceiling fan	80 W	6	36	
Treatment Room	100 44	11	80	
Light fitting	6 W	6		
Ceiling fan	80 W	1	36	
Ladies common To	ilet	1	80	
Tube lights	20 W	12		
Light bulb	10 W	2	40	
Geyser	2000 W	1	10	
Visitor Dining Room	2000 W	1	2000	
Tube lights	20 W	T		
Ceiling fan	80 W	1	20	
Store	00 W	1	80	
Tube lights	20 W			
Ceiling fan		1	20	837
Doctors Room	80 W	1	80	
Tube lights	20 111	-		
Ceiling fan	20 W	1	20	
Nurse Duty Room	80 W	1	80	
Tube lights	20 111			
Ceiling fan	20 W	1	20	
config fall	80 W	1	80	
Total				
			20952 W	

Operation Theater Section

Electrical Load	Wattage	Numbers	Total	
OT Pantry		rumbers	Total consumption(Watts)	Remark
Tube lights	20 W	1	20	
Light bulb	10 W	1		
Aqua-guard	25 W	1	10	
Doctor Lounge		1	25	
Tube lights	20 W	1	20	
Ceiling fan	80 W	1		
OT In-charge		1	80	



Tube lights	20 W	11	20	
Ceiling fan	80 W	1		
Post Operative	1	L	80	
Light fitting	15 W	8	120	
Ceiling fan	80 W	2		100
Patient Monitor	90 W	4	160	
Post Operative			360	
Light fitting	15 W	8	120	
Ceiling fan	80 W	2		
Patient Monitor	90 W	4	160	
		+	360	

OT Passage:

Electrical Load Light Fittings	Wattage	Numbers	Total (Watte)	Daniel
Light Fittings	36 W	17	612 W	Remark

Operation Theater No. 1 (Emergency Surgery)

Electrical Load	Wattage	Numbers	Takel (TV)	
Light Fittings	36 W	Aumbers	1	Remark
OT Lamps	94 W	4	144	
Patient warmer		1	94	54+40
Anesthesia work station	600 W	1	600	
	1840 W	1	1840	
Cautry Machine	400 W	1	400	
Patient monitor	90 W	1	90	
Suction Machine	85 W	1		
Pass box	50 W	1	85	
X-ray viewer	45 W	1	50	
Total	43 W	1	45	
			3348 W	

Operation Theater No. 2 (Orthopedic Surgery)

Electrical Load	Wattage	Numbers	Takal ON	
Light Fittings	36 W		Total (Watts)	Remark
OT Lamps		6	144	
	94 W	1	94	54+40
Torricate machine	230 W	1	230	31170
Anesthesia work station	1840 W	1	1840	
Cautry Machine	400 W	1		
Patient monitor		1	400	
Suction Machine	90 W	1	90	
	85 W	1	85	
Pass box	50 W	1	50	
X-ray viewer	45 W	1		
X-ray image intensifier		1	45	
it tay image intensifier	3450 W	1	3450	

Total		
Total	1 (100)	
	6428 W	1

Operation Theater No. 3

Wattage	Numbers	Total (Watta)	l n
	7	(, , , , , ,	Remark
	1		
	1		54+40
	1		
	1		
	1		
	1	600	
	1	760	
	1	575	
85 W	2	170	
200 W	1		
50 W	1		
	-		
	36 W 94 W 100 W 700 W 230 W 600 W 760 W 575 W 85 W 200 W	36 W 7 94 W 1 100 W 1 700 W 1 230 W 1 600 W 1 760 W 1 575 W 1 85 W 2 200 W 1	36 W 7 252 94 W 1 94 100 W 1 100 700 W 1 700 230 W 1 230 600 W 1 600 760 W 1 760 575 W 1 575 85 W 2 170 200 W 1 200

Operation Theater No. 4

Electrical Load	Wattage	Numbers	Total (NV //)	Γ=
Light Fittings	36 W	6	(Remark
OT Lamps	108 W	1	216	
Anesthesia work station	1840 W	1	108	54+40
Cautry Machine		1	1840	
Patient monitor	760W	1	760	
	90 W	1	90	
Suction Machine	85 W	1	85	
Pass box	50 W	1	50	
X-ray viewer	45 W	1		
HD Camera	138 W	1	45	
HD Monitor		1	138	
Patient warmer	150 W	1	150	
	600 W	i	600	
Total			3812 W	

Operation Theater No. 5

Electrical Load	Wattage	Numbers	Total (NY)	T
Light Fittings	36 W		(Traces)	Remark
OT Lamps		6	144	
X-ray viewer	94 W	1	94	54+40
	45 W	1	45	31110
LED light source	120 W	1	120	
LCD Monitor	69 W	1		
CO ₂ Insufflators	27 CO. C.	1	69	
	1150 W	I	1150	
Anesthesia work station	1840 W	1	1840	



		4890 W
Total	000 W	600
Patient warmer	600 W 1	
	50 W 1	50
Pass box		150
HD Monitor	150 W 1	138
HD Camera	138 W	
	90 W 1	90
Patient monitor		400
Cautry Machine	400 W 1	1400

Operation Theater No. 6

Electrical Load	Wattage	Numbers	Total (W	-
Light Fittings	36 W	6	(/ * * * * * * * * * * * * * * * * * *	Remark
OT Lamps	94 W	0	216	37.5
X-ray viewer	25 75 757	1	94	54+40
	45 W	1	45	- 10
X-ray image intensifier	3450 W	1	3450	
Torricate machine	230 W	1		
Anesthesia work station	2300 W	1	230	
Cautry Machine	400 W	1	2300	
Patient monitor		1	400	
Pass box	90 W	1	90	
	50 W	1	50	
Total			6803 W	

Operation Theater No. 7

Electrical Load	Wattage	Numbers	Total (NV)	
Light Fittings	36 W	q	(, , , , , ,	Remark
OT Lamps	40 W	9	324	
Anesthesia work station		11	40	54+40
FECO machine	1840 W	1	1840	
		2	al e	
Microscope		2		
Suction Machine	85 W	1	85	
Pass box	50 W	1	LANGE CONTRACTOR OF THE PARTY O	
X-ray viewer	45 W	1	50	
Total	13 44	1	45	
			3348 W	

Operation Theater No. 8

Electrical Load	Wattage	Numbers	Total OV	
Light Fittings	36 W	1	()	Remark
OT Lamps	94 W	4	144	
X-ray viewer		1	94	54+40
LED source	45 W	1	45	
	600 W	1	600	
Anesthesia work station	1840 W	1	1840	
Cautry Machine	200 W	1	200	
Patient monitor	90 W	1	90	



Pass box	60 W		
Total	50 W 1	50	
10441		3063 W	

Operation Theater No. 9 (Septic OT)

Electrical Load	Wattage	Numbers	T-4-1 OV	
Light Fittings	15 W	Cambers	- (Remark
OT Lamps		0	90	
X-ray viewer	94 W	I	94	54+40
	15 W	1	15	31110
Anesthesia work station	600 W	1	600	
Cautry Machine	200 W	1		
Patient monitor		1	200	ii 535,742,000
Total	600 W	1	600	
Total			1590 W	

OT Rooms:

Rooms	(20 W) Tube light	(00 HDE		
Male changing room	1	(80 W)Fan	(10 W)Bulb	Total
Resident Interns	1	1	-1 -	110 W
OT staff	1	1	1	110 W
OT store	1	1	_1	110 W
Female consultant	1	1	_1	110 W
Female Resi. & Interns	1		hin and	110 W
Toilet	0		1	110 W
Total	U	U	1	10 W
				670 W

Counseling Room:

Electrical Load	Wattage	Numbers	Total	
Tube lights	20 W	1	City of Month Character and Control of Street	Remark
Ceiling fan	80 W	1	20	
Coffee maker	1200 W	1	80	
Microwave oven	1400 W	1	1200	
X –ray viewer	45 W	1	1400	
CPU + Display	175 W	1	45	
Total	173 W	1	175	
			2920 W	

OT Store:

Electrical Load	Wattage	Numbers	Total consumption(Watts)	Гр
Tube light	20 W	1	20 (watts)	Remark
fan	80 W	1	20	
Total			100 W	



Post operating Room:

Electrical Load	Wattage	Numbers	Total consumption(Watts)	D 1
	20 W	3	60	Remark
fan	80 W	2	160	
Total			220 W	

OT Passage and Toilet

Electrical Load	Wattage	Numbers	Total	
Light fitting	36 W	2	Total consumption(Watts)	Remark
CFL Lamp	12 W	2	72	
Total			96 W	Toilet

Pre-operative Room:

Electrical Load	Wattage	Numbers	Total congress to CV	
Tube light	20 W	2	- Tonsamption (valus)	Remark
fan	80 W	3	60	
		2	160	
X –ray viewer	45 W	1	15	
Patient Monitor	345 W	1	43	
Total			345	
			610 W	

HOD Room:

Electrical Load	Wattage	Numbers	Total	
Tube lights	20 W	1	Tomberon (vy atts)	Remark
CFL Bulb	10 W	1	20	
Ceiling fan	80 W	1	10	
X -ray viewer	36W	1	80 36	
TV set	70 W	1		
Printer	700 W	1	70	
CPU + Display	175 W	1	700	
Total		1	175	
			1091 W	

Store (2):

Electrical Load	Wattage	Numbers	Total	
Tube lights	20 W	2	- Tomour peron vvalls)	Remark
Ceiling fan	80 W	1	40	
X -ray viewer	20 W	1	80	Toilet
Total	20 W	1	20	
Total			140 W	



First Floor X- ray section:

Passage:

Electrical Load Tube lights	Wattage	Numbers	Total (W-44)	D
Tube lights	20 W	2	40 TV	Remark
8-1-15	20 VV	2	40 Watts	

Bio-Medical Room:

Electrical Load	Wattage	Numbers	Total	
Tube lights	20 W	2	- Tombumphon (valls)	Remark
Ceiling fan	80 W	1	40	
CPU + Display	175 W	1	80 175	
Printer	600 W	1	600	
Printer	700 W	700	700	
Total		700	1595 W	

Associate Professor Room:

Electrical Load	Wattage	Numbers	Total	
Tube lights	20 W	2	- Tombuilding walls)	Remark
LED bulb	10 W	1	40	
Ceiling fan	80 W	1	10	
Wall fan	50 W	1	80	
CPU + Display	175 W	2	50	
Printer	600 W	1	350	
X –ray viewer	36 W	1	600	
Total	30 44	1	36	
			1166 W	

Museum:

Electrical Load	Wattage	Numbers	Total agreement	
Tube lights	20 W	2	Total consumption(Watts)	Remark
Ceiling fan	80 W	1	80	
X –ray viewer	36 W	6	216	
Total			336 W	

Washing Room:

Electrical Load	Wattage	Numbers	Total	
Tube lights	55 W	1	Total consumption(Watts)	Remark
Washing machine	470 W	i i	470	
Washing machine	1800 W	1		9.5 kg.
Total	1000 (1	,	1800	5.5 Kg
			2325 W	

Housekeeping store:

Electrical Load	Wattage	Numbers	Total	
Tube lights	20 W	1	Total consumption(Watts)	Remark
CPU + Display	175 W	1	175	
Total			195 W	

Central sterile Room:

Electrical Load	Wattage	Numbers	Total	
Tube lights	20 W	9	the consumption walls	Remark
Tube lights	55 W	-	180	
Tube lights	45 W	4	220	
Exhaust fan		1	45	
Ceiling fan	50 W	2	100	
Culindria 1.4	80 W	2	160	
Cylindrical Autoclave	18000 W	2	36000	
Cylindrical Autoclave	9000 W	1	9000	
Flash Autoclave	3000 W	I		
ETO Sterilizer	4500 W	1	3000	
Periclave	20 W	1	4500	-
Printer	92 W	2	40	
Ultrasonic Cleaner		1	92	
Drying Cabinet	2000 W	1	2000	
Form Cabinet	805 W	1	805	
Other side of X-ray s	ection:		56142 W	

Passage & Bathroom:

Electrical Load	Wattage	Numbers	Total	
Tube lights	20 W	2	- System brion (A Sitts)	Remark
Ceiling fan	80 W	3	60	
Light fitting		2	160	
Tubo linta	15 W	3	45	
Tube light Total	18 W	1	18	D
Total			278 W	Bathroom

Seminar Room:

Electrical Load	Wattage	Numbers	Total consumit	
Tube lights	20 W	2	- Tonsumption (vy atts)	Remark
Ceiling fan	80 W	1	40	
Projector	700 W	1	80	
X-ray viewer	36 W	5	700	0
Total			180	
			1000 W	

Professor and HOD Room:

Electrical Load	Wattage	Numbers	Total	
Tube lights	55 W	2	- Consumption (vy atts)	Remark
LED bulb	10 W	1	110	
Ceiling fan	80 W	1	10	
CPU + Display	175 W	1	80	
Printer	700 W	1	175	
X –ray viewer	36 W	1	700	
Total	30 W	3	108	
- Otta			1183 W	

Professor Room:

Electrical Load	Wattage	Numbers	Total	
Tube lights	55 W	1	(Silk AA Mondamperon (AA Silk)	Remark
Tube lights	20 W	1	33	
Ceiling fan	80 W	1	20	
X –ray viewer		1	80	
Total	36 W	2	72	
Total			227 W	

X-ray Room (500 mA)

Electrical Load	Wattage	Numbers	Total	
X-ray Machine	29050 W	1	Total consumption(Watts) 29050	Remark
Tube lights	20 W	1		
Ceiling fan	80 W	1	20	
X –ray viewer	36 W	1	80	
Total	30 W	1	36	
			29186 W	

X-ray Room (800 mA)

Electrical Load	Wattage	Numbers	Total	_
Tube lights	55 W	2	18118 AA MONTHUM AN SILE	Remark
Tube lights	20 W	,	110	
Ceiling fan		1	20	
	80 W	1	80	
X -ray machine	80000	1	80000	
X –ray viewer	36 W	2	72	
TV Display	70 W	1	70	
Total			80352 W	



X -ray Room (300 mA)

Wattage	Numbers	Total	
	1	The constitution (walls)	Remark
	1	33	
	1	80	
32000	1	32000	
36 W	1		
	-	The state of the s	
	55 W 80 W 32000	55 W 1 80 W 1 32000 1 36 W 1	55 W 1 55 80 W 1 80 32000 1 32000

X-ray Room (800 mA)

Electrical Load	Wattage	Numbers	Total	
Tube lights	55 W	4	the consumption (watts)	Remark
Ceiling fan	80 W	2	220	
X -ray machine	80000	1	80000	
X -ray viewer	36 W	1	36	4.00
TV Display	70 W	1	70	
Total ther Rooms:			80486 W	

Other Rooms:

Room	Tube link (20 xxx	i -	-
Library	Tube light(20 W)	Fan(80 W)	Remark
Store	1	1	100 W
Store	1	1	100 W
Ladies Toilet	1	1	100 W
Gents Toilet	2	0	40 W
Reading Hall	23	0	40 W
Housekeeping Changing		12	1420 W
Total	2	0	40
			1840 W

Lecture Hall:

Electrical Load	Wattage	Numbers	Total (Watts)	Dans 1
Spot light	8 W	32	256	Remark
Spot light	10 W	40		
Public Address System	100 W	1	400	
Projector		1	100	
Total	700 W	1	700	
. otal			1456 W	

Medical Record Section:

Electrical Load	Wattage	Numbers	Total	
Tube lights	20 W	Q	Tonsumption (valls)	Remark
Tube lights	45 W	2	160	
Ceiling fan	80 W	4	90	
CPU +Display	175	5	320 875	
Printer	600	1	600	
Total			2045 W	

SECOND FLOOR:

Passage:

Electrical Load	Wattage	Numbers	Total consumption(Watts)	
Light Fitting	15 W	32	480	Remark
Light Fitting	36 W	14	1224	
Ceiling fan	80 W	12	960	
Tube lights	15 W	4	60	CIGIL
Total			2724 W	SICU Passage

Male Surgery Ward:

Electrical Load	Wattage	Numbers	Total	
Tube lights	20 W	16	Total consumption(Watts)	Remark
Zero watt bulb	15 W	6		
Ceiling fan	80 W	13	90	
Water cooler	100 W	2	960	
Total	100 11	2	200	
			1570 W	

Sister Room:

Electrical Load	Wattage	Numbers	Total consumption(Watts)	
	20 W	1	20	Remark
Ceiling fan	80 W	1	80	
Total			100 W	



Doctor Room:

Wattage	Numbere	Total	
20 W	1	Tombumpuon (Walls)	Remark
80 W	1		
100 W	1		
	-		
	20 W	20 W 1 80 W 1	20 W 1 20 80 W 1 80

Pantry:

Electrical Load	Wattage	Numbers	Total community (7)	
Tube lights	20 W	1	Total consumption(Watts)	Remark
Ceiling fan	80 W	1		
Suction machine		1	80	
Total	30 11	1	85	
76.			185 W	

Treatment Room:

Wattage	Numbers	Total comment	
20 W	1	The sound in bright At SIGN	Remark
80 W	1		
24 W	1		
	-		
	20 W 80 W	20 W 1 80 W 1	20 W 1 20 80 W 1 80

Toilet:

Electrical Load	Wattage	Numbere	Total	
Tube lights	20 W	3	Total consumption(Watts)	Remark
LED Bulb	10 W	3	60	
Total			20 80 W	

Ward 2:

Electrical Load	Wattage	Numbers	Total comme	
Tube lights	20 W	12	Total consumption(Watts)	Remark
Zero watt bulb	15 W	4		
Ceiling fan	80 W	9	60	
Total			720	
Tube lights	20 W		1020 W	
Tube lights	27 (327) 8 81	1	20	Store 1
Tube lights	20 W	1	20	Store 2
rate lights	20 W	1	20	Male changing



Tube lights	20 W	1	20	
Light fitting	36 W	2	72	laboratory
Fan	80 W	2		Demo Room
Light fitting	36 W	3	160	Demo Room
Fan	80 W	1	108	Demo Room2
LED Bulb	10 W	2	80	Demo Room2
X -ray viewer	60 W	1	20	Demo Room2
Tube lights	20 W	1	60	Demo Room2
LED Bulb	10 W	12	20	Burn ward Passage
Fan	80 W	12	20	Room1
Tube lights	20 W	$+\frac{1}{i}$	80	Room1
LED Bulb		$\frac{1}{2}$	20	Room1
Fan	10 W	2	20	Room2
CPM machine	80 W	1	80	Room2
Infrared le	35 W	1	35	
Infrared lamp Total	200 W	1	200	Room2
rotar			1055 W	Room2

Third Ward:

Room	Tube light(20W)	Fan(80 W)	I ED D. B. com	
General ward	23	13		Total (W
Store	1	13	4	1540
Treatment	1	1	- 12 A.7.5	100
Nurse duty room	1	1	- 18:47-114-3	100
Store	1	1	- 452	100
Store	1	1	- 17 SA SA	100
Bathroom	3	1	- 0.2	100
Ladies bathroom	1-	-	- 108264	60
Clerk	1	-	1	10
Professor Room	$\frac{1}{1}$	1	-	100
Professor Room	1	1	1	110
Associate Prof.	2	1	1	110
Associate Prof.	1	1	1	130
Asst. Prof.	1	1	1	110
Asst. Prof.	1	1	1	110
Museum	1	I	1	110
B-209	4	1	-	100
Γotal	-	1	1 4500	170
Other Equipments on	this word			3160 W
Light fitting	48 W			
Spot light	0.171	1	48 W	Passage
Thumb print scanner	5 W		4	- abouge
CPU +Display	155 ***		5	Asso. Prof.
Printer	COO ***	2		HOD
	000 W	2	(00	Asso. Prof.

X –ray viewer	36 W	1	
Total		36	B-209
		120 W	

SECOND FLOOR MEDICINE WARD

Room	Tube light(20W)	Fan(80 W)	Dull-(1517)	
General ward 1	18	13		(')
Nurse duty room	1	1	4	1460
Changing Room	1	1 1	- 22	100
Treatment Room	1	1	- 260	100
Bathroom	2		-	100
Ward No. 2	12	1	3	165
Store	12	10	4	1100
Clinical Demo Room	2	1	-	100
Store	1	2	- "	200
Corona ward		1	-	100
General ward	24			4
Ladies bath room	4	13	6	1610
Stores		-	- 7	80
Stores	1	1	-	100
Treatment Room	1	1	- 6.0	100
pantry	1	1	Escare I	100
Doctors Duty Room	1	1	-	100
Stores	1	1	- 1	100
Clinical Demo	1	1	_	100
emilical Demo	2	1	- 00	120
Total				120
				5025 11/
Other Equipments on the				5835 W
Geyser	2000 W		2000	D. J.
entilator	300 W			Bathroom
-ray viewer	36 W			Ward 2
otal			36	Clinical demo
			4136 W	

SECOND FLOOR MEDICINE WARD:

Room	Tube light(20W)	Fan(80 W)		
General ward 1	18		Bulb(15W)	Total (W)
Nurse duty room	10	13	4	1460
Changing Room	1	1	- 10-11	100
Treatment Room	1	1	- 12	100
Bathroom	2	1	- 36	100
Ward No. 2	12	1	3	165
Store	1	10	4	1100
Clinical Demo Room	2	1		100
TO TOOM	4	2	- 42	200



Seminar Room				
Light fitting	15 W	8	120	
Ceiling Fan	80 W	1	80	
Stores				
Tube light	20 W	1	20	
Fans	80 W	1	80	
Total			7662 W	
THIRD FI	OOR			

Passage:

Electrical Load	Wattage	Numbers	Total consumption(Watts)	Remark
Tube light	20 W	8	160 W	-
			160 W	

"C" Wing

Room	Tube light(20W)	Fan(80 W)	Tube light(55 W)	Total (W
Clinical Demo Room	1	1	-	100
Storage	1	1	_	100
Pediatrics	12	9	_ 37	960
Histology	¥.			900
Puva chamber	1	1	_	100
Associate Professor	1	1	-	100
Associate Professor	1	1	-	100
Pediatrics	1	i	-	100
Passage			11	10,000,000
Total			11	605 1005 W

Psychiatric Ward:

Room	Tube light (55 W)	Fan (80 W)	Tube light (20 W)	Tube light (36 W)	Total (W)	
V. 33 - 1	Psychiatric	OPD				
Doctor duty room	2	1		_	190	
Asst. Professor	1	1	-	- 3	135	
Asst. Professor	2	1	-	_	190	
HOD	2	1			190	
Professor room	1	1			135	
	Psychiatric Ward:					
Ward	_	5	6	-	520	
Toilet			2	2	112	
Seminar room	1-	1	1		100	
Psychiatric ward	5	7	3	_	895	



Clinical demo room 1 Recovery Room 2	1 (x-ray reader)	136
Total 2	1	180
ECT Room:	(F)	2783 W

ECT Room:

Electrical Load	Wattage	Numbers	Total	
Tube lights	55W	1	- Tomoumption (vv atts)	Remark
Ceiling fan	80 W	1	55	
ECG machine	24 W	1	80 24	
Monitor	70 W	1	70	
ECT machine	1150 W	<u> </u>	1150	-
Total			1379 W	

DEMO ROOM:

Electrical Load	Wattage	Numbers	Total community (1)	
Light Fitting	72 W	12	- Tombumpuon (valls)	Remark
Ceiling fan	80 W	0	864	
Projector	The state of the s	8	640	
	700 W	1	700	
Total			2204 W	

SKIN DISESEASES HOD ROOM:

Electrical Load	Wattage	Numbers	Total	
Tube Light	55 W	2	town brion (as sets)	Remark
Ceiling fan	80 W	1	110	
CPU +Display	175	1	175	
Printer	600	1	600	
Total		_	965 W	

Asst . professor Dermatology:

Electrical Load	Wattage	Numbers	Total	
Tube Light	20 W	2	ton (watts)	Remark
Ceiling fan	80 W	1	40	
CPU +Display	175	1	80	
Printer	700	1	700	
Total	, 00	1	700	
			995 W	



PUVA Chamber:

Wattage	Numbers	Total	
	2	- Tomouniperon (Walls)	Remark
	1		10-210-00-00
Carrier Carrier	1		
			
	•		
	Wattage 55 W 80 W 2400 W 125 W	55 W 2 80 W 1 2400 W 1	55 W 2 110 80 W 1 80 2400 W 1 2400

Asst. Professor Dermatology:

Electrical Load	Wattage	Numbers	T	
Tube Light	55 W	14dimbers	the state of the s	Remark
Ceiling fan	Contract Dates	2	110	
	80 W	1	80	
Cosmo laser machine	20 W	1	20	
Derma india Mega surg	40 W	1		
Pedestal Light	36 W	1	40	
Total	30 W	1	36	
			286 W	
Asso Professor			-90 11	

Asso. Professor

Electrical Load	Wattage	Numbers	Total consumption (W.	T
Tube Light	55 W	2	Total consumption(Watts)	Remark
Ceiling fan	80 W	1	80	
Total			190 W	

Pediatrics Chamber:

Electrical Load	Wattage	Numbers	Total consum d'	to the second
Tube Light	55 W	2	Total consumption(Watts)	Remark
Ceiling fan	80 W	1	80	
CPU +Display	175	1	175	
Printer	14	1	14	
Total			379 W	2 10

Gynecology Ward:

Wattage	Numbers	Total	
	7	The same of the sa	Remark
	11		
	15		
200	1		
	1		
	1		
	Wattage 55 W 20 W 80 W 10 W 85 W	55 W 7 20 W 11 80 W 15 10 W 1	55 W 7 385 20 W 11 220 80 W 15 1200 10 W 1 10



Artist Room:

Electrical Load	Wattage	Numbers	Total consumption (N)	T =
Tube light	20 W	1	Total consumption(Watts)	Remark
Ceiling fan	80 W	i	80	
Total			100 W	

Third Floor: Pediatrics Ward

Passage and Toilet

Electrical Load	Wattage	Numbers	Total (Watts)	n .
Tube light	20 W	12	(, , , ,	Remark
LED Bulb	10 W	12	160	4:in toilet
	2000	2	20	
Geyser	2000 W	1	2000	
Aquarium pump	3.5 W	1	3.5	
TV set	70 W	1	(
Set top box		1	70	2
	17 W	1	17	
Total			2270 W	27-0 . 4 .

Ward No. 1

Electrical Load	Wattage	Numbers	Total (Watts)	n
Tube Light	55 W	13	()	Remark
Bulb		13	715	ward
	15 W	4	60	
Ceiling fan	80 W	13	1040	
Tube Light	20 W	1		2
LED Bulb	Harmon Control	7	80	Toilet 2
	10 W	2	20	Toilet 2
Total			1915 W	Tonet 2

ICU:

Electrical Load	Wattage	Numbers	Total (Watts)	Remark
Fridge	125 W	2	250	
Public address system	100 W	1	100	ward
Ceiling fan	80 W	2		
Tube Light	20 W	4	160	
Total	20 W	4	80	Toilet 2
. otti			590 W	

Clean ICU:

Electrical Load	Wattage	Numbers	Total (Watts)	D 1
Warmer	600 W	6	3600	Remark
Patient monitor	90 W	5	450	
LED Photometry	600 W	2	1200	
Ceiling fan	80 W	2	160	



Tube Light	20 W			
Total	20 W	2	40	Toilet 2
Total			5450 W	- 5.00 2

Septic ICU:

Electrical Load	Wattage	Numbers	Total (W)	T
Warmer	600 W	1	- (· · · · · · · · · · · · · · · · · ·	Remark
Patient monitor	90 W	6	2400	
Exhaust Fan	35 W	6	540	6
		2	70	
LED Photometry		3	1800	
Ventilator	300 W	3	900	
Ceiling fan	80 W	2	160	
Tube Light	20 W	2		
Total	20 11	2	40	Toilet 2
			5910 W	

Mother feeding room:

Electrical Load	Wattage	Numbers	Total (Watts)	Down I
-0-10	20 W	1	20	Kemark
Fan	80 W	1	80	
Total			100 W	

Step down Room

Electrical Load	Wattage	Numbers	Total (Watts)	D
Tube light	20 W	1	(11 22223)	Remark
Fan	80 W	1	20	
Ventilator	300 W	1	80	a short in
Photo therapy Unit	- X 72 C 20 C 10 C 10 C 10 C 10 C 10 C 10 C 1	3	900	
Warmer		3	648	
	600 W	3	1800	
Incubator	100 W	1	100	
Total		-		
			3548 W	

Doctors Duty Room:

Electrical Load	Wattage	Numbers	Total (TV	
Tube light	20 W	1	(Trucks)	Remark
Fan		1	20	
	80 W	1	80	
Pedestal fan	50 W	1	50	
Total			150 W	



ICU 3:

Electrical Load	Wattage	Numbers	Tr. 1 1 av	
ECG Machine	24 W	1 dilibers	(Remark
Exhaust Fan	35 W	1	24	
Defibrillator	70 W	2	70	
Weighing Scale	15 W	1	70	
Suction machine	85 W	1	15	
Ventilator		1	85	
Ceiling fan	300 W	1	300	
Tube Light	80 W	4	320	
	55 W	1	55	
Tube Light	20 W	3	60	Toilet 2
Total			999 W	Tonet 2

Clinical Demo Room:

Electrical Load	Wattage	Numbers	Total (Watts)	Pomal
Tube light	20 W	1	20	Remark
Fan	80 W	1	80	ALK N
X –ray viewer	36 W	i	36	
Total			136 W	

Doctor Duty Room:

Electrical Load	Wattage	Numbers	Total (Watts)	D -
Tube light	20 W	1	20	Remark
Fan	80 W	1	80	100
Total			100 W	

Clinical Demo Room 2:

Electrical Load	Wattage	Numbers	Total (IV)	-
Tube light	20 W	1	(174663)	Remark
Fan		4	80	No.
	80 W	1	80	
Projector	700 W	1	700	
X -ray viewer	36 W	1		
Total	20 11	1	36	
- otal			895 W	

Pantry:

Electrical Load	Wattage	Numbers	Total (Watts)	
Tube light	20 W	1	Total (Watts)	Remark
Fan	20 11	1	20	
Total	80 W	1	80	
Total			100 W	

Treatment Room:

Electrical Load	Wattage	Numbers	Total (West)	D
Tube light	20 W	1	(Tracts)	Remark
Fan	80 W	1	40	
Suction pump	85 W	1	80	
Weighing scale		1	85	H
Total	15 W	1	15	
Total			220 W	

Store:


Electrical Load Tube light	Wattage	Numbers	Total (Wotte)	I D
	55 W	1	55	Remark
Fan	80 W	1	80	
Total			130 W	

Pulmonary Lab:

Electrical Load	Wattage	Numbons	Total (Watts)	
Tube light	20 111	rumbers	I otal (Watts)	Remark
	20 W	1	20	i i i cii i
Fan	80 W	1	00	
Total	00 11	1	80	
Total			100 W	

NICU Ward:

Electrical Load	Wattage	Numbers	Total (W. (L)	
Feeding Ward	0	- Landers	Total (Watts)	Remark
Tube light	20 W	5	100	1/2-18-11
Fan	80 W	4	100	1 in passage
LED Bulb	10 W	2	320	ta A e i p
NICU Ward	1-5	2	20	
Tube light	20 W	3	(0)	
Tube light	55 W	10	60	
Fan	80 W	17	550	
X -ray viewer	36 W	1	136	14.14
Treatment room	2011	1	36	
Tube light	55 W	1		
Fan	80 W	1	55	Tro pr
Laboratory	00 W	1 1	85	
Tube light	55 W	1		
Fan	80 W		55	
Pantry	OU W	1	85	



			2877 W	1
	85 W	1	85	
uction Machine		4	360	
Monitors	90 W	1		
an	80 W	7	560	
ube light	20 W	9	180	
halesamia Ward			100	- 1 m
Tube light	20 W	3	60	
Ladies Bathroom			63	
Fan	80 W	1	85	
Tube light	45 W	1	45	

Third Floor ENT Section:

Electrical Load	Wattag	ge Number	rs Total (Watts)	Remai
Electrical Pane			(Tructs)	Ticinal
Tube light	55 W	1	55	1
ENT passage			1	
Tube light	20 W	3	60	Τ
Fan	80 W	1	80	
Table fan	50 W	1	50	
Fridge	125 W	1	125	
Monitor	70 W	1	70	
ENT Store			170	
Tube light	45 W	1	45	1 19
Suction machine	85 W	1	85	
ENT Ward			03	
Tube light	20 W	24	480	
Fan	80 W	8	640	
Treatment Room	n	1,0	040	
Tube light	20 W	1	20	Part of the
Fan	80 W	Ti Ti	80	
Clinical Demo R	oom		00	
l'ube light	20 W	4	80	-
Fan	80 W	2		
X -ray viewer	36 W	1	160	
Optho Passage		1 -	36	
Tube light	20 W	3	60	
an	80 W	2	60	A
Ortho Ward		2	160	
ube light	20 W	5	100	
ube light	45 W	7	100	
ube light	55W	3	315	
	80 W	14	165	
reatment Room	20 11	14	1120	
1	55W	1		
	J J VV	1	55	



Fans	80 W	1	00	_r
Doctor on Du	ty Room	1	80	
Tube light	55W	1	55	Revise a
Fans	80 W	1	80	-
Clinical Demo	Room	1.	100	
Tube light	55W	1	55	4.0
Fans	80 W	ti		
Total		+	80	
			4291 W	

Third Floor Nursing Staff Hostel:

Electrical Load	Wattage	Numbers	Total (Watts)	T D
Passage			1 otal (watts)	Remark
Tube light	20 W	8	160	
Water cooler	125 W	1	125	
Water Dispenser	90 W	1	90	
Wash room1,2,3			90	
Tube light	20 W	1	20	
Tube light	20 W	5	100	No.1
Tube light	20 W	2		2
Hostel Ward		12	40	3
Tube light	45 W	20	1000	
Fan	80 W	19	900	
Hostel	00 11	19	1520	= =
Room No.1				
Tube light	45 W	1	45	. = 100 - 200 - 200
Fan	80 W	1	45	
Room No. 2	00 11	1	80	
Tube light	45 W	1		
Fan	80 W		45	196
Room No. 3	OU W	1	80	
Tube light	45 W	, ,		
Fan	80 W	1	45	
Room No.4	00 W	1	80	
Tube light	15 111			
an	45 W	1	45	
otal	80 W	1	80	
Otta			3455 W	

Fourth Floor

Corona ward

Passage and Bathroom:

Electrical Load	Wattage	Numbers	Total (Watts)	I D
Tube light	20 W	6	(italis)	Remark
Tube light		0	120	Passage
	20 W	2	40	
Tube light	55 W	2		Ladies
Total	35 11	4	110	Gents
Total			270 W	

Electrical Load	Wattage	Numbers	Total (Watts)	D 1
Ward 1			Total (Watts)	Remark
Tube light	20 W	14	280	
Light fitting	72 W	12	864	(26.11)
Ceiling fan	80 W	15	1200	(36 W X2
X -ray viewer	36 W	1	36	
TV set	80 W	1	80	
Set top box	17 W	1	17	
Ward 2			17	
Tube light	20 W	7	140	1885
Tube Light	55 W	8	440	
Ceiling fan	80 W	12	960	
Treatment room		12	900	
Tube Light	20 W	1	20	
Ceiling fan	80 W	1	20	
Store	- 1	1	80	
Tube Light	55 W	1	55	ck.ol
Ceiling fan	80 W	$\frac{1}{1}$	55	
Nurses on duty		-	80	
Tube Light	55 W	1		
Ceiling fan	80 W	1	55	
Library	00 11	1	80	
Tube Light	20 W	1	20	
7 111			20	
Ward No. 3			80	
Tube light	20 W	2	10	
7 1 11 1			40	
			45	
1 11: 0			715	
tores	70 VV	12	960	
	15 W 1			
antry	15 W		15	



			8270 W	
X –ray viewer	60 W	1	60	
Ceiling fan	80 W	1 .	80	
Tube Light	20 W	1	20	
Professor			1,00	
Printer	700 W	1	700	
CPU + Display	175 W	1	175	
Ceiling fan	80 W	1	80	7.00
Tube Light	45 W	1	45	
Professor and H	OD			
Ceiling fan	80 W	1	80	
Tube Light	45 W	1	45	
Associate Profe	ssor		00	
Ceiling fan	80 W	1	80	
Tube Light	45 W	1	45	
Asst. Professor			133	
Tube light	45 W	3	135	
Passage				
Set top box	17 W	1	17	-
TV set	80 W	1	80	
X -ray viewer	36 W	1	36	
Ceiling fan	80 W	2	160	
Tube Light	20 W	2	40	
Demo Room			100	
Ceiling fan	80 W	1	80	
Tube Light	20 W	1	20	

Ladies Hostel Rooms:

Electrical Load		Numbers	Total (Watts)	T.D.
Passage + Bathro	om	11110013	Total (watts)	Remark
Tube Light	45 W	4	180	
Tube Light	45 W	2		Passage
Room No. 401,40	2 403 404	111/24-1	90	Bathroom
LED bulb	10 W	, 411(attach		1112 11
Ceiling Fan	80 W	2	20	
TV set		1	80	
Set top box	80 W	1	80	
Total	17 W	1	17	
			197 W X 5 = 985 W	
Koom No. 405, 40	06,407,408,4	409, 410 (wi	197 W X 5 = 985 W	2027
	10 W	1	10	2011)
Ceiling Fan	80 W	1	80	
TV set	80 W	1	80	
Set top box	17 W	\dot{i}		
Total		1	17	
			187 W X 5 =935 W	



Fourth Floor Nursing Boy's Hostel:

Electrical Load	Wattage	Numbers	Total (VV	
Reception	8-	rambers	Total (Watts)	Remark
Tube Light	20 W	1	120	
Doffing area	1	1	20	Reception
Tube Light	20 W	3	60	
Ceiling Fan	80 W	3	240	-
LED bulb	10 W	2	20	
Room Number 41	2.413.414.4	115 (Attach	11 11	
Tube Light	20 W	1	d bathroom facility) Ea	ach room has
Ceiling Fan	80 W	1	20	
LED bulb	10 W	2	80	
TV set	80 W	1	20	
Set top box	17 W	1	80	
Total		1	17	
Room Number: 41	64174194	10.420	217 W X 4 = 868 W	
Tube Light	20 W	19,420	ally	
Ceiling Fan	80 W	1	20	
LED bulb	10 W	1	80	
ΓV set	80 W	1	10	
Set top box	17 W	1	80	
Total			17	
	Foundly El		207 X 5 = 1035 W	

Fourth Floor General Ward:

Passage and Toilet:

Electrical Load	Wattage	Numbers	Total (W. 44.)	
Tube Light	55 W	11	Total (Watts)	
Tube Light	55 W		605	Passage
LED bulb	10 W	2	105	
Total	10 W	1	10	
· Otal	-		720 W	
Room Number	Tube Light(45W)	E- (00 H)	40.50	
1	1 doc Eight (43 W)	Fan(80 W)		Additional
2	1	1	125	
3	1	1	125	
. 4	1	1	300	CPU +Display
5	2	1	170	er o i Dispia
6	1	1	125	
7	3	1	215	
	3	1	251	V
8	2	1	170	X -ray viewer
9	2	1		
10	2	1	170	
		1	206	X -ray viewer



11	1	1	125	
Ward 1	6	4	590	
Ward 2	6	4	590	
Ward 3	12	12	1597	TDV C
Pantry	1	1	125	TV, Set Top
Store	1	1	125	
Treatment Room	1	1	125	
Duty Doctor Room	1	1	125	
Total			5259 W	
Wanta			3239 VV	
Ward 4				
Tube Light	20 W	10	200	
Fan	80 W	12	960	
TV Set	70 W	70	4900	
Set Top Box	17 W	17	289	
Light Fitting	72 W	12	864	(26 77)
CFL fitting	36 W	12	432	(36 W x 2)
Total			7645 W	
21: 1			7043 **	
Clinical Demo Roor				
ight Fitting	72 W	2	144	
`an	80 W	$\frac{1}{1}$	80	(36 W x 2)
-ray Viewer	36 W	1	36	
aboratory			30	
ight Fitting	72 W	2	144	·
an	80 W	$\frac{2}{1}$	80	(36 W x 2)
reatment			180	
ight Fitting	72 W	2	13.1	
an	80 W	1	144	(36 W x 2)
tore		1	80	
ght Fitting	72 W	2		
an	80 W	2	144	(36 W x 2)
otal	00 //	1	80	
			932 W	

Total load of fourth floor is KW

FIFTH FLOOR (Intern Hostel)

Electrical Load	Wattage	Numbers	Total (Watts)	Remark
Passage and Toil	et:		(Traces)	Remark
Tube light	20 W	19	380	Dagge
Fan	80 W	1	80	Passage
TV set	80 W	1	80	
Water cooler	110 W	1	110	
Geyser	2000 W	1	2000	
Tube light	20 W	4	80	T 11
			00	Toilet
Cafeteria				
Tube light	20 W	5	100	
Fan	80 W	1	80	
Fridge (pepsi)	340 W	1	340	
Fridge (Coca-cola)	275 W	1	275	
Kitchen grill	1500 W	1		
Microwave	1400 W	1	1500	
Induction Heaters	2000 W	2	1400	
Mixer	500 W	1	4000	
	300 W		500	
Gents Hostel (Room	n No. 501	510) 10 =		
Gents Hostel (Room	20 W	5 5 18) 18 Ro		
Fan		1	20	(In each
	80 W	1	80	Room)
			$100 \times 18 = 1800 \text{W}$	
adice Hostel. (D				
Ladies Hostel: (Roc	m No.601			
	6 W	12	72	Passage
ight fitting			36	Bathroom 1
ight fitting		6	36	Bathroom 2
Beyser	2000 W	1	2000	
adies Hostel:				Bathroom 2
ube light	20 W	1	20	(1
an	80 W		80	(In each
			$100 \times 18 = 1800 \text{W}$	Room)
			100 Y 19 - 1800 M	
otal				

Lift Room:

Electrical Load	Wattage	Numbers	Total (Watte)	D .
Tube light	55 W	2	(1,466)	Remark
Electric Motor	7500 W	2	110	
		1	7500	
Electric Motor	11000 W	1	11000	
Electric Motor	7500 W	1	7500	
Total		-		
			26110 W	

Male Resident Doctors Hostel:

Electrical Load		Numbers	Total (Watts)	TD.
Common passag	ge	T THINGE IS	Total (watts)	Remarl
Tube light	55 W	2	110	
Ceiling fan	80 W	1	80	+
Light fitting	6 W	4	24	
Male Resident A	rea: Passa	ge	24	
Light fitting	6 W	15		T
Water Cooler	100 W	1	100	
TV set	80 W	1	80	-
Set top box	17 W	i	17	
Tube light	20 W	20	400	
Light fitting	6 W	8	48	
Ceiling fan	80 W	3		Gym
Light fitting	12 W	7	240	Gym
Resident Rooms	(1 to 22)	/		Pool
Light fitting	6 W	8	10	1
Ceiling Fan	80 W	2	48	
-	20 11	2	160	
Total			208 X 22=4576 W	7.11
- 5 (6)			5883 W	

Female Resident Doctors Hostel:

Wattage	Numbers	Total (Watter)	10
e	1.dilibers	Total (watts)	Remark
	14	280	Т
	1		
	1		1
	1		
2009 1980 3	0		
			Gym
			Gym
24 to 48)	/	84	Pool
6 W	8	10	
	e 20 W 6 W 100 W 80 W 17 W 6 W 80 W 12 W 24 to 48)	e 20 W 14 6 W 10 100 W 1 80 W 1 1 6 W 8 8 80 W 3 12 W 7 24 to 48)	e 20 W 14 280 6 W 10 60 100 W 1 100 80 W 1 80 17 W 1 17 6 W 8 48 80 W 3 240 12 W 7 84 24 to 48)

Ceiling Fan	80 W	2	160
Title			208 X 22=4576 W
Total+			5693 W

Main Staircase Lighting

Electrical Load	Wattage	Numbers	Total (Watts)	Remark
Tube light	55 W	2	110	Kemark
Tube light	20 W	5	100	-
Light fitting	6 W	3	18	
Total			228 W	

Medical Gas Unit:

Electrical Load	Wattage	Numbers	Total (Watts)	Damanl
Tube light	45 W	2	90	Remark
Ceiling Fan	80 W	1	80	
Air Compressor	1·1000 W	i	11000	
Air Compressor	3700 W	1	3700	
Vacuum compressor	7500 W	1	7500	
Vacuum compressor	3700 W	1	3700	
Total			26070 W	

It is observed that Average ON time of compressor = 1.347 minutes

Average OFF time of compressor = 7.595 minutes

Theoretical Capacity of the compressor is = 2.83168 m^3 per minute

Leakage Quantity =
$$(1.347 / \{1.347 + 7.595\}) \times 2.83168$$

$$= 0.426557 \text{ (m}^3 / \text{minute)}$$

$$= 615 \, \text{m}^3 \, / \, \text{day}$$

Specific power for compressed air generation = 11 KWh / (2.83168×60) m³ /day = 0.0647 KWh / m³

Energy lost due to leakage / day = $0.0647 \text{ KWh / m}^3 \text{ x } 615 \text{ m}^3/\text{day}$

$$= 39.81 = 40$$
 Units per day

Energy lost due to leakage / month = 1200 Units



Average cost of Unit is Rs. 13.441235

Loss in terms of Rupees = $1200 \times 13.44 = 16,128$ /- Rupee.

Laundry Section:

Electrical Load	Wattage	Numbers	Total (Watts)	Remark
Common passage		1 · · · · · · · · · · · · · · · · · · ·	Total (Watts)	Kemark
Tube light	55 W	10	550	
Wall mounted fan	80 W	6	480	
Washing machine	1500 W	2	3000	
Hydro machine	2200 W	1	2200	
Washing machine	2200 W	2	4400	
Hydro machine	3700 W	2	7400	
Dryer Tumber	2600 W	2	5200	
Flat bed press machine	10800 W	1	10800	
Calendar Machine	460800 W	1	460800	
Pressing Iron	2000 W	1	2000	
Total	N.	1	496830 W	

Central Store:

Electrical Load	Wattage	Numbers	Total (Watts)	Remark
Tube light	55 W	5	275	Remark
Almond wall Fan	100 W	2	200	
Pedestal fans	50 W	2	100	
CPU + Display	175 W	3	525	
Printer	700 W	1	700	
Total			1800 W	

Hospital Canteen:

Electrical Load	Wattage	Numbers	Total (Watts)	Remark
Tube light	20 W	7	140	Kemark
Fridge	100 W	1	100	
Ceiling fan	80 W	1	80	
Wall fan	50 W	1	50	
Total			370 W	



Other Canteens:

Electrical Load	Wattage	Numbers	Total (Watts)	Remark
Kitchen 1				1
Tube light	20 W	5	100	
Cola Fridge	275 W	1	275	
Pepsi fridge	340 W	1	340	
Ceiling fan	80 W	1	80	
Popcorn Oven	2000 W	1	2000	
Mixer	500 W	2	1000	
Kitchen 2				
Tube light	20 W	3	60	
Ceiling fan	80 W	1	80	14
LED Bulb	10 W	1	10	
Fridge	150 W	1	150	
Pepsi fridge	340 W	1	340	
Ceiling fan	80 W	1	80	
Popcorn Oven	2000 W	1	2000	
Mixer	500 W	1	500	
Microwave oven	1400 W	1	1400	
Tower Fan	100 W	1	100	
Induction Heater	1500 W	1	1500	
Kitchen 3			1500	
Tube light	20 W	2	40	
Magbon LED	50 W	1	50	
Microwave oven	1400 W	1	1400	
Fridge	150 W	1	150	
Mixer	500 W	1	500	-
Pepsi fridge	340 W	1	340	
Front Sitting Area		•	310	
Tube light	20 W	9	180	
Ceiling fan	80 W	9	720	10.54
Total		-	13395 W	

Workers Shade:

Electrical Load	Wattage	Numbers	Total (Watts)	Remark
Tube light	20 W	1	20	Strain of a
Ceiling fan	80 W	1	80	148
Welding machine	4200 W	1	4200	
Cutter machine	300 W	1	300	1000
Drilling Machine	500 W	1	500	
Total			5100	

For Gawade Electricals

Proprietor (Sanjay P. Gawade)





ENERGY SAVING OPPORTUNITIES IN HOSPITAL.

I) Hospital management recognize the importance of having an effective cooling systems to keep patients and staff comfortable. It is often possible to reduce energy wastage while improving internal comfort conditions at the same time. Setting appropriate temperatures, ensuring that cooling equipment and controls are operated and managed correctly can help reduce costs. In fact, it is possible for the hospital to save up to 30% on cooling costs through the implementation of energy saving measures.

Obtain Feedback

Encourage staff to report any areas that are too cold or draughty. Investigating those problematic areas can help to identify operation and maintenance issues. If these issues are addressed, the hospital staff and patients are less likely to adjust the temperatures by opening windows while cooling is on, or opening the door of the air conditioned rooms frequently during cooling is going on. Therefore in order to maintain appropriate internal temperatures, the temperature settings should be in accordance to the activity taking place in the area. A good starting point is to know the recommended temperatures for specific areas in hospitals as mentioned below.

Room Type	Temperature ⁰ C	Relative Humidity
Operation theatres	17–27	45-55%
Recovery Rooms	24–26	45-55%
Patients Rooms	24–26	45-55%

REDUCE HEAT GAIN

If you are thinking that how to make your air conditioner work more efficiently, then Reducing the Heat Gain can be another way. To improve your air conditioners efficiency is to reduce the heat gain. Here are some easy ways to reduce AC's heat gain.

Seal Air Leaks

If the room is leaky, it is difficult for AC to work effectively cool it. If room is older, there's a good chance it's never been air-sealed. Air sealing of the room will help your heat gain problem, especially if there are leaks on your ceiling because heat rises.



· Keep the Sun out

If your room is getting direct sunlight, that can really affect your cooling loads. So make sure you shade your windows, especially if they are getting east or west exposure. It's best to shade your window from the outside, but indoor shading also works.

Get More Efficient Lights and Appliances

Electric appliances and lights are great but they also waste a lot of heat that gets added to your room. Take incandescent lights, for example, these lights convert almost 90% of the electricity used into heat. Or if you've been holding on to your old fridge, if you replace it with a newer model, you will save a ton on your electricity bills.

Move Appliances to Other Areas

If there is a room in your home that is already overheating due to perhaps too many west-facing windows, that might not be the best place to put your new IT appliance. The heat in that room could become unbearable, so relocate those appliances to cooler areas.

4. INVEST IN ENERGY EFFICIENT HVAC EQUIPMENT

You can double and even triple your return on investment when you replace a system that is at least 10 years old. Newer AC models have high BEE ratings. This means these newer systems are more HVAC energy efficient.

Today's AC's BEE ratings are usually around 14 to 18. This is a huge improvement from the units that were made a decade ago. You also might want to look out for Energy Star-rated models. These models follow strict guidelines and are incredibly efficient.

IMPROVE AIR CONDITIONER EFFICIENCY

Just as it's important to reduce heat gain, you also want to make efforts in your air conditioned room to improve your heat removal. Here are a couple of easy steps you can do to help remove heat from your room.

Please note that these steps only work if your AC is already properly functioning.

Replace Dirty Filters

When something is wrong with your Air Conditioning Unit and you call an HVAC service person the first thing they will check is the status of your filters. So you might as well do this on your own frequently as a good maintenance habit.

If your filters are dirty, then airflow is reduced which means there is less cooling happening in your room. Dirty filters can even reduce your airflow so much that it freezes your air conditioning coil which can damage compressor.

Maintenance people can avoid this problem altogether if they keep an eye on AC filters, and clean or replace them when they get dirty.



· Keep The Vents Clear

When you choke off ac airflow, vents increase their pressure in the duct system and then air flow is reduced throughout your home. You want to make sure that all return and supply vents in your ac are able to easily move air.

You also want to check to make sure all AC louvers are open. Don't close vents in rooms you're not using. That only creates a problem.

PRESERVE AIRFLOW

Looking for how to maximize air conditioning efficiency? You can help your HVAC energy efficiency by simply keeping your units clean and clear of leaves, dust, and debris. You also want to make sure that vents are not getting blocked by any objects or furniture. When you preserve airflow it's important to the efficiency of your AC unit.

BE VIGILANT ABOUT MAINTENANCE

When you regularly maintain your AC (before there's a problem) this keeps your equipment running efficiently and maximizes your HVAC energy efficiency. You want to keep seasonal maintenance appointments at the beginning and end of the heating and cooling season. You will also save money this way from expensive repairs.

TWEAK YOUR THERMOSTAT

Chances are you won't notice when your AC goes up or down one degree Fahrenheit. People usually aren't aware of small changes in temperature. Your AC can be a lot more efficient if you simply adjust the temperature closer to the outside one.

If it's hot outside, an HVAC that is set to 75 degrees will use 18% more energy than one set that is set at 78 degrees. And when you set your system to 72 degrees then 39% more energy is being used than if it was set to 78 degrees.

You'll want to turn your AC up more when there is no one in your home. Which is why again programmable thermostats make controlling the temperature of your home super easy.

CHANGE AIR FILTERS

This is worth repeating since blocked air filters commonly cause HVAC energy efficiency issues. If a filter gets clogged, then your equipment uses more power and runs longer. Filters trap dust before it can damage parts when it enters the system.

When your filter gets clogged, dust can get collected on motor parts and fan blades which slows down your unit and wastes electricity.

POWER DOWN ELECTRONICS

When you're not using electronics like computers, machinery, media systems, and exercise equipment, you're going to want to turn them off. Not only will this save you energy, but these electronics also generate a lot of heat. Which means, your AC will use less energy to cool down your space when these items are turned off.

Even when you're not using electronics, these devices can draw a lot of energy simply by being plugged in. It is found, constantly-plugged-in devices account for five to ten percent of total residential energy use.



Lighting

Effective lighting is essential for healthcare staff to carry out their work properly, yet it is possible to achieve significant savings in this area and improve the quality of the lit environment.

Lighting can account for over 20% of the total energy use of the electricity used in a typical hospital. Good lighting design can reduce costs and have the added benefit of decreasing internal heat gains, thus reducing the need for air conditioning too.

The lighting of healthcare buildings requires specific knowledge of a wide range of light sources and lamp types. Normal standards and methods of lighting may not be appropriate. If in doubt, always seek professional advice before making major changes to a lighting system.

Switch Off' Policy

Involve all staff in making energy and cost savings. As part of an awareness campaign, conduct regular meetings, place suitable stickers above light switches and put posters up in the staff areas.

Make a member of staff responsible for going around at set times during the day to check lighting. For example, a morning check would include making sure that external lights are switched off, if there is sufficient daylight.

Label Light Switches

Help staff to select only those lights they need, by labeling light switches suitably. As part of general policy, lights in unoccupied areas should be switched off but remember to consider health and safety implications, particularly in corridors and stairwells. Key areas for security lighting include pharmacy drug stores, laboratories and residential accommodation.

Maintenance

Without regular maintenance, light levels can fall by 30% in 2–3 years. Keep windows, skylights and light fittings clean. Replace old, dim or flickering lamps and keep controls in good working order by ensuring timers are set correctly and that any occupancy sensors are clean. Encourage staff to report maintenance issues. This will help maintain the desired light output and, in turn, provide a safer, more attractive environment for both staff and patients.

Install Low-Energy Lighting

Upgrade lights to the most efficient suitable options. For example, at many locations in the hospitals, any 'standard' tungsten light bulbs can be upgraded directly to energy saving compact fluorescent lamps (CFLs) which use 75% less energy, produce less



unwanted heat and last 8–10 times longer. Replace blackened, flickering, dim or failed fluorescent tubes with tri-phosphor coated ones. Tri-phosphor coating provides a more natural, brighter light for the whole life of the tube. If the tubes are 38mm (1.5 inch), replace them with slimmer 26mm (1 inch) tubes or T5, (5/8th of an inch) fluorescent lamps.

Specify high frequency fluorescent lighting systems and mirror reflectors whenever fluorescent lighting is to be replaced. This should be included in the hospital's purchasing policy. High frequency tubes reduce energy use and heat output, eliminate flicker and hum, extend lamp life (by up to 50%) and can allow dimming — all of which can make a ward more comfortable.

Always consult a qualified lighting specialist before upgrading lighting systems and refer to BEE Star labeled lamps to ensure it is efficient.

Switching in Parallel

Hospitals tend to have a lot of windows, particularly in wards and in consulting areas. This provides a good opportunity to maximize daylight. Wire lights so that those closer to the windows can be switched off, while the rest remain on with separate controls. This is called 'switching in parallel' and enables staff and patients to make the most of natural daylight, which is usually preferred. As a result, less lighting is used, reducing energy consumption and additional heat generated by the lights, which, in turn, means that less cooling is required.

Occupancy Sensors

Occupancy sensors ensure light	s only operate when there is somebody there to req	
them. These are especially usefu	il in, for example, the following spaces:	luire

- Intermittently used office areas
 - Toilets and washroom facilities
- Storerooms
- Areas where lighting is zoned.
- Occupancy sensors can also be used to lower light levels in corridors at night time, which can be an effective cost-saving measure. However, it is imperative to maintain minimum light levels so as not to compromise health and safety standards.
- Occupancy sensors may not be appropriate for wards and in patient rooms where people may not be moving frequently enough to be detected.



Office and Small Power Equipment

Office and small power electrical equipment may account for more than 10% of total electricity use within, the hospital.

Office and IT equipment is widely used in hospitals, particularly in administration section and reception areas. Other common small power appliances include equipment such as kettles. electric cookers, toasters, microwaves and other electrical appliances including vending machines, televisions, vacuum cleaners, etc.

Turn off and Power Down

Where equipment is left on unnecessarily there are opportunities to make significant savings. Switch off all equipment when not in use and enable power-down modes. This reduces the energy consumption and heat produced by equipment, lowering cooling costs and improving staff and patient comfort. The lifespan of this equipment will also be extended, and the risk of breakdown reduced.

Seven-day timers

These only cost little but reduce the likelihood of machines being left on out of hours. They can be fitted to photocopiers, printers, drinks and vending machines. Check with your equipment supplier first about any service agreements particularly in vending machines.

Maintain Equipment

Check and clean all heat-emitting equipment regularly, including keeping filters free of dust. This is not just to improve cleanliness and appearance; dirt can reduce the effectiveness of equipment and affect it's cooling down process. Seek advice from the manufacturer on servicing schedules in order to maintain optimum efficiency.

Catering

Water and energy usage in catering department are areas that can offer major energy savings without compromising hygiene or resources.

Efficient catering facilities can reduce the energy requirement per meal significantly. Energy consumption in kitchens can represent more than 10% of total hospital energy usage. This is equivalent to 1-2 kWh/bed/day.² Managing consumption can have additional benefits of improving the quality of the food produced as well as the working environment for kitchen staff.

Raise Awareness amongst Kitchen Staff

Do not switch on too soon — most modern catering equipment reaches optimum temperature quickly. Label equipment with its preheat time and educate staff to switch on only when required



Avoid using catering equipment to warm the kitchen space on staff arrival in winter months

Switch off heating and cooking equipment immediately after use

Avoid overfilling saucepans and kettles, and use lids where possible

Keep fridge and freezer doors closed and defrost at manufacturers' recommended intervals to save energy and prolong equipment lifetime

Switch off equipment, lights and exhaust fans when they are not being used.

Purchase Equipment with running costs in Mind

Although gas-fired equipment is often more expensive to buy than electrical or steam equivalents, savings made on running costs make it an attractive option. Equipment that automatically switches off, such as pan sensors on hobs, can save on energy costs. Select ovens with large, double-glazed viewing windows to reduce the need to open doors to inspect contents.

When purchasing any domestic-sized catering equipment such as fridges, freezers or dishwashers refer to BEE efficiency label and always look for the most efficient rated models.

Consider Heat Recovery

Large volumes of warm air are expelled from kitchens. Many managers do not realize that heat can be recovered using heat recovery devices, which can significantly reduce energy costs. An air- to-water recovery device is often the most effective method of recovering heat because it can then preheat hot water, providing a year-round use for the recovered heat.

Maintain Kitchen Extract Ventilation

Ventilation units and extractor hood grease filters should be kept free from dust and grease and cleaned at regular intervals, as recommended by the manufacturer. Regular cleaning of ventilation systems can increase efficiency by as much as 50% compared with unmaintained systems. There is also a reduced risk of breakdown.

Monitor with Sub-Meters

Sub-metering kitchen areas can provide an extra incentive for staff to be efficient, by showing how energy is used in this facility and how subsequent efforts have paid off. Catering in hospitals is at times outsourced so there is the additional benefit of allowing for budget allocation and charging to take place.



Laundry

Laundry facilities are extremely energy-intensive. With an average of three kg of dry laundry per bed per day, laundries are big consumers of steam. They may account for as much as 10-15% of a hospital's total energy consumption in large modern hospitals.³ Water usage is also an important issue. Make sure that laundries are targeted in the sitewide energy strategy. Some actions to consider are listed below:

- Most steam-heated laundries will generate excess low-grade heat that can be conveniently re-used elsewhere across the site
- Water recovery by recycling the rinse water from washer extractors is a proven means of reducing water usage
- Total water recovery is becoming more acceptable and should be investigated
- Heat recovery via heat exchangers from hot effluent is standard practice and can be used on all types of machine
- Consider energy efficient motors in place of ordinary motors, as they are less heated, less noisy, and highly efficient. Although they are 15 to 20 percent costlier than ordinary motors, this high initial cost can be easily returned in few months.

Specialist Equipment

The specialist nature of a hospital environment means that there is a significant amount of energy-intensive equipment, such as medical fridges, mortuary and pharmacy cold stores, laboratory equipment, X-ray, CAT-Scan, MRI machines, etc.

Each specialty area will have a wide range of equipment. Since each item requires careful evaluation, and because of the potential risks to the welfare of the patients, this Audit Report does not provide in-depth guidance on this topic. However, careful purchasing, along with maintaining good housekeeping practices can generally keep consumption to a minimum, as detailed in the action points below.

Portable Medical Equipment

While being both convenient and cost-effective, portable medical equipment can cost hospitals in terms of energy use. Fortunately, energy performance can be tackled in several ways:

Establish a purchasing policy — choosing the most efficient equipment will reduce energy use and heat gains.

Raise awareness of energy management techniques — encourage staff to switch off devices when they are not being used, or to make use of built-in standby or power-down modes.

Building design — deal with heat gains generated by medical equipment in the context of the building's overall design strategy. For example, instead of



Choosing sterilizing and disinfecting equipment on the basis of energy usage as well as Performance — energy usage and whole-life cycle costs can differ widely between manufacturers

Insulating sterilizer bodies and pipe-work connections, valves, flanges and so forth, to minimize standby losses

Metering the department for each utility and specifying individual energy metering for each major washer and sterilizer.

Motors and Drives

Motors are generally running out of sight, sometimes constantly, every day of the year. The value of the electricity consumed by an electric motor over its life is typically 100 times the purchase price of the motor itself. It is therefore important to ensure that motors (and their associated drives) are as efficient as possible.

Considerable energy savings can be achieved by good system design to minimize the motor load. A small increase in duct or pipe size can significantly reduce system losses and thus greatly reduce the fan or pump power required.

Low-loss motors, variable-speed controls and effective control can realize substantial savings. Replace old elevator machinery with variable frequency drive.

Replace reciprocating type compressor by screw type compressor.

Building Envelope

Considering the age and outdated design of many hospital buildings, it is not surprising that some can be inefficient.

Identifying and repairing problems quickly can help avoid expensive problems batter on

Typically, two thirds of Energy (for cooling/heating) from a hospital is lost through the building envelope, with the remaining third being lost through air infiltration and ventilation. The rate at which energy is lost depends on:

The temperature difference between inside and outside

The insulation properties of the building envelope

The amount of fresh air entering the building either by controlled ventilation or through poorly fitting windows, doors or joins in walls

Improving building envelope in a hospital makes good sense for many reasons:



- Better temperature control it can lower cooling and ventilation costs and prevent overheating
- Enhanced patient comfort a more comfortable ward gives patients the best conditions for a faster recovery
- Improved productivity staff morale and output can be enhanced by providing a more comfortable working environment through reducing draughts, solar glare, overheating and noise
- Lower capital expenditure a more efficient, well insulated hospital needs smaller heating and cooling plant
- A brighter, cleaner environment this may help increase patients' confidence in the care the unit is providing.

Undertake Regular Maintenance

Identify potential building envelope problems as part of routine maintenance and deal with them promptly. In particular, repair gaps or holes in walls, windows, doors and skylights immediately. Preventing the loss of heated or cooled air provides instant savings and also improves the appearance of a hospital. It is more comfortable for staff and patients too.

Establish a Housekeeping Schedule

- Compile a regular checklist to address areas where energy is lost via the building structure. If the hospital is large, it would be worth delegating this to several members of staff, all of whom can work from the same checklist. A comprehensive schedule includes checking walls, floors, roofs and skylights, doors and windows, including frames and panes.
- Keep windows and external doors closed as much as possible when cooling/heating is on and consider sealing unused doors or windows to further reduce draughts.

Regularly Check the Building for Dampness and Moisture Damage

- Moisture can cause significant damage to the building structure and reduce its insulating properties. It is also unsightly and even though it may not reflect the quality of the healthcare offered, patients could be concerned by what appears to be dirty and unkempt premises.
- Prolonged dampness can lead of mould growth, which can be very dangerous for the health of patients and hospital staff.
- Repair split down-pipes, faulty gutters and leaky roof tiles as soon as an issue becomes apparent. Do not just opt for a quick fix repair the cause and save time on expensive work later on.
- Regularly check for signs of damp and condensation at least once a year, preferably prior to winter months.



Check and Maintain Insulation

Ensure that hot water and heating pipes are insulated. Similarly, check accessible loft spaces to make sure that insulation is in good condition and replace if required. As well as saving energy by reducing heat loss from the pipe, insulation can also improve internal comfort by reducing the risk of overheating.

AIR CONDITIONING MAINTENANCE CHECKLIST

SITE:

AIR CONDITIONING SYSTEM

ENTER OK OR NEEDS ATTENTION (N/A) 1 2 3

OK N/A OK N/A OK N/A

DUCT CHECK CONDENSATION

DUCT CLEAN R/A GRILLS AND PLENUM BOX

DUCT CHECK SUPPLY & R/A GRILLS & CLEAN

DUCT CHECK FOR AIR LEAKS & VIBRATION

EVAP CLEAN DRIPTRAYS & FLUSH

EVAP CLEAN R/A FILTERS

EVAP CHECK PUMPS ON CASSETTE UNITS

EVAP REPLACE DISPOSABLE FILTERS IF FITTED

EVAP CHECK COIL FOR DIRT BUILD UP

EVAP CHECK FAN OP & VIBRATION/BELTS

COND CHECK FANS

COND CHECK COMP MOUNTS/VIBRATION

COND CHECK FOR OIL LEAKS & PIPEWORK

COND CHECK CONDITION OF CONDENSERS

COND CHECK REFRIGERANT CHARGE

COND CHECK ELEC/TIMERS CONTS & O/LOADS

COND CHECK WIRING A & TERMINALS

COND CHECK OPERATION COOL/HEAT

GENERAL

CHECK T/STAT & SETTING

GENERAL

CHECK PIPE & INSULATION

GENERAL

CHECK OPERATION OF EXHAUST FAN

GENERAL.

INFO

AL CHECK SIGNS OF WATER LEAKS RECORD ALL COMPS SUCTION PRESSURES

INFO RECORD OUTDOOR AMBIENT TEMP

INFO RECORD SUPPLY AIR TEMPS

INFO RECORD MAKE & MODEL OF A/C UNITS

INFO RECORD TYPE OF SYSTEM

SPLIT

DUCTED -

CASSETTE

COMMENTS

CLIENT SIGNATURE:

STORE STAMP

TECHNICIANSIGNATURE

DATE:



There are total 124 Numbers of 55 W Tube lights with old fashioned choke and starter facility, in this premises in working conditions .

If it is assume that, these tube lights are working for 8 hours per day on an average.

Then these tube lights consume, $(124 \times 55 \times 8 / 1000) = 54.56$ Units per day. Remember, our per unit cost is Rs. 13.44/- Therefore the cost of this consumption is, $54.56 \times 13.44 = 733$ /- Rupee per day. That means, 21998 /- Rupee per month.

If we replace these tube lights by energy efficient 20 W LED Tube lights, Then the same expense cut down to, $(124 \times 20 \times 8 / 1000) \times 13.44/-=$ Rs. 267 /- per day That means 217 x 30 = 7999 /- Rupee per month.

There is a saving of Rs. 21998–7999 = 13999/- Rupee. Per month.

Similarly, there are 101 numbers of 45 W Tube lights (With electronics Ballast),

If these tube lights are replaced by same 20 W tube lights, then we can save,

 $(101 \times 8 \{45-20\}/1000) \times 13.44) = 271$ Rupee per day, that means Rs.8145 /- per month.



SAFETY AUDIT REPORT OF D.Y.PATIL HOSPITAL CAMPUS

Sr	General Information	Particulars to be	TD 1
No.		submitted	Remark
1	Name of Hospital	D. Y. Patil Medical College Hospital and	
2	Hospital owner's Name and address	Research Institute, Kolhapu 507, E Ward, Kadamwadi, Kolhapur	
3	Telephone Numbers:	0231 265 5663	
4	Email id:	dypatilmedicalcolleg	ge@gmail
5	Hospital type- (Private/ Govt. /Municipal /Trustee/ Charity)	Private	
6	Name of The Contact Person in (Emergency'/(Mobile No.)	Day: Night:	
7	No of total operating staff shift wise	1 st Shift: Shift:	2 nd
8	No. of other staff: Ensure staff are able to obtain an MSDS	All the nursing staff obtain a Material Saf Sheet (MSDS); a technology document that provide detailed information controlled, or hazard product.	fety Data hnical les on a
9	No. of security staff shift wise:	1 st Shift: 15 2 nd Shift: 9 3 rd Shift: 9	
10	Hospital beds capacity:	1000 Beds	
11	Hospital Specialty if any	Multi specialty Hospi	ital
12	Building height in Meters. Total built up area in Sq. Meters. Total built up area of each Floor Sq. Meters. (including Basement) No. of floors (e.g. Basement +Ground + Stilt + 3 Upper Floor)	Approximately 2500 Sq. ft.	
13	No of Internal Staircase: 1 Width of Internal Staircase: six feet No. of External staircase: 3	No of Internal Stairca Width of Internal Stai feet	[10] 전 10] 12]

	Wild CD	
	Width of External Staircase: six feet No. of Ramps: 2 Width of Ramp: 6 feet No. of Toilet blocks on each floor: Ground, First, Second, Third, Fourth Floor has 3 Ladies and 3 Gents Toilets Fifth and Sixth Floor has 2 Ladies and 2 Gents Toilets	No. of External staircase: 3 Width of External Staircase: six feet No. of Ramps: 2 Width of Ramps: 6 feet Number of Toilet Blocks on each floor: Ground: 1st Floor: 2nd Floor: 3rd Floor 4th Floor 5th & 6th Floor
14	No. of Lifts with capacity- 3 Capacity: 780 Kg	Passenger Lift: 2 Fire Lift: Stretcher Lift: 1
15	Annual maintenance contract	Yes
16	Implementation of suggestion, (if any)	-
17	Incinerator location (if any)	No waste material is burned, it is disposed.
18	Canteen/pantry/kitchen location and area —	In the same campus. 1000 Feet ² (approximately)
20	Burn Ward: if any – Capacity ICU Location and Capacity OT Location and Capacity Storeroom Location, Area Type/details of material stored in storeroom (acids/alkalis/toxic/inflammable/ etc)	Burn Ward: if any -Capacity ICU Location and Capacity OT Location and Capacity It is verified that all of the chemicals and any other flammable liquid materials are stored securely in glass bottles and plastic cans kept in a wooden cabinet, which is properly locked. Area of this
21	Spirit Storage details- all flammable material is stored appropriately?	cabinet is 800 square feet (approximately) It is Ensured that no unauthorized heat producing equipment is present in store room. Flammable material is
22	Cylinders gas name, quantity, etc.: O ₂ = large, small CO ₂ =Small cylinders N ₂ = Cylinders	Materials must be stored appropriately.



23	Radiological material /machinery, I f any-	T
23	Radiological material /machinery, I f any- name, qty, storing place, etc.	No
24	No. of maximum patients accommodated in the building-	1000
25	Type of pressurization and No. of change cycles	NO (A pressurization system is intended to prevent smoke leaking passed closed doors into stairs by injecting clean air into the stair enclosure such that the pressure in the stair is greater than the adjacent fire
26	Air conditioning Location (if central A/c) Air conditioning Location and Number for Split And Window air conditioners.	Compartment.) There are total 45 numbers of split type air conditioners. Outdoor units of the AC are kept in duct. Total AC tonnage is 440 TR. All the air-conditioners must be switched on with the help of MCB-switch socket instead of ordinary switch socket provided at present.
28	Name of the service provider for AC maintenance: Mr. Amol Upashe Whether his personnel are qualified / skilled?: All are Skilled.	It is found that, annual maintenance contract has been signed for the preventive maintenance of AC.
29	Location of the meter Room, Status of the panel, Inside Wiring	Meter room is located on the left of the building. Wiring in the panel found in good condition.
30	Age of the Hospital: C	British Era Period i) A Post Independence ii) B Up to 1970 From 1970 -2008 2008 Onwards IV) D
31	Did hospital face any fire disaster in the past? if yes submit action plan.	Hospital did not face any kind of fire disaster in past
32	Whether fire fighting agency is recruited or not?	If yes, Name, United Sales



		Talant	10
	*	Telephone	Corporation,
		Number,	Shahupuri,
		other details.	Kolhapur.
33	Number and two CC		9422049621.
33	Number and type of fire extinguishers Per floor,	6 Kg ,ABC ty	
	per dept.	extinguishers a	
		in following manner:	
		42 on ground f	floor, 12 on
		first floor,7 No	o. on second
		floor.9 on thir	d floor
		6 on 4 th & 5 th I	Floor, 2 on 7th
		0 in Record re	
		0 near DG set	t.
		Smoke detec	ctors on
		Ground floor	
		Smoke detect	tors on first
		floor	
		Smoke detect	tor on second
		floor	**************************************
34	Labels and conditions of the fire Extinguishers.	Pressure	Labels on the
		meter	fire
	*	indicator is in	extinguishers
		green zone.	are properly
		*Last date of	visible.
2.5		refilling	* 18/01/2021
35	Is every exit, exit access or exit discharge is	Yes, every exit	exit access or
	continuously	exit discharge i	
	maintained free of all obstructions (4.2.3)	maintained free	
		obstructions.	71
36	Emergency exit way, evacuation gathering	Emergency exit	ways are
	points	defined, signs a	re also
	defined /provided ?	provided for the	e same.
		Emergency gath	
		not definedP	lace seems to
		be the suitable p	
		same.	Jaco for the
37	Is every wall opening protected with fire-	All the doors in	the hospital
	resisting doors having the fire rating of not	are fire proof ar	
	less than 2 h (IS 3614-Part I), all doors opening	properly.	id are obeimig
	t	property.	



	properly?	
38	Sprinklers and smoke alarms are operational?	
39	All fire exit signs are illuminating properly?	1
40	Doors to materials rooms are closed locked?	Yes
41	Doors are propped open appropriately?	Yes
42	Stairways meet safety standards ?(mention Number of stairways) Free of obstacles? Step surfaces are not slippery Carpet intact (if applicable) Hand rails fixed and in good condition All aisles and floors are free of obstruction	This hospital has 1 internal and 3 external staircases. Internal staircases are of smooth black marble and external staircases are made by MS plates and pillars. External staircases are shaded and their rusting process is in progress. Painting and sheltering is required. Step surfaces are not slippery. Hand rails are fixed and found in good condition. All the aisles, staircases are free of obstructions
	Electrical Safety:	or contractions
43	General conditions of electrical panels, main switch, electric motor board and change over switch, A/Cs, water cooler, water filter, wiring cables etc. is good and all DBs, panels, switch boards are properly covered?	Yes, Medical equipments are fitted in ordinary switch sockets, instead of switch socket with MCB. This change is very important.
44	Whether penalty is being imposed in electricity bills on account of higher load / poor power factor etc. (check Electricity bills of April, May, June, July month) Additional electrical load required if any from power distribution company) Whether preventive maintenance of electric installation and account of higher load / poor power factor account installation and account of higher load / poor power factor etc. (check Electricity bills of April, May, June, July month) Additional electrical load required in account of higher load / poor power factor etc. (check Electricity bills of April, May, June, July month) Additional electrical load required in account of higher load / poor power factor etc. (check Electricity bills of April, May, June, July month) Additional electrical load required if any from power distribution company)	No(penalty has been imposed for the reason of poor power factor, or for additional power requirement from the supplying agency other than contract demand.) Yes
	installation and equipment is carried out by skilled licensed holder electricians / skilled technicians.	
46	Whether MCCBs/MCBs/ELCBs are provided with proper ratings to cover the load?	Yes All the MCBs are of proper rating and are in good

 \leftarrow



	CL 1 II I I I	*
	Check all electrical outlets are in good condition	condition.
47	Is the emergency lighting system capable of continuous operation for a minimum duration of 1 hour ?(or for the time suitable to Hospital)	Yes
48	Is the emergency lighting provided to be put on within 1 second of the failure of the normal lighting supply. (4.16.3)	Yes(ensure that lamps on operating table put on within one second of the mains failure, other lighting system recover within 10 seconds after DG Set get activated.)
49	Is emergency lighting powered from a source independent of that supplying the normal lighting as per IS 9583	Yes. Emergency lighting is provided by an inverter and DG Set.
50	Is emergency lighting system provided in the following location 1) Near each intersection of corridors 2) At each exit doors 3) Near each change of directions in the escape route. 4) Near each stair case, so that each flight of	1) Yes 2) Yes 3) Yes 4) Yes
	stairs receives direct light. 5) Near any other change of floor level. 6) Outside each final exit and close to it 7) Near each fire alarm call point. 8) Near fire fighting equipment.	5) Yes Near floor level change6) Yes7) Yes8) Yes
51	Is the emergency lighting luminaries mounted 2 meters above the floor level?	Yes
52	Is staircase and corridor lighting connected to alternate supply probably running on batteries which are continuously trickle charged by a charger?	Yes. Alternate (standby) supply for staircase and corridor is on DG Set.
53	Whether water seepage is observed near any of the electrical panel, distribution boards, electrical equipments etc.?	No
54	Whether Earthing pits are provided and connected to the equipment body of the connected equipment?	Yes
55	Whether earthing pits are properly maintained?	Advised them to regularly

 \bigcap_{i}

 \leftrightarrow



56	Whether the contact numbers of persons, electricians, power distribution company, Generator service provider, vendor, UPS Vendor, A/C service provider/ fire fighting agency are available with Reception / Security guard and other staff and they are displayed in	pour 10 bucket full water +10 Kg salt in earth pit once a month. No
57	Electric room / Reception ? Whether the power factor correcting panel of appropriate rating is installed?(APFC Panel)	Yes
58	Generator has capacity to meet 100% of demand? Verify that the generator begins to operate within seconds of the hospital losing power demands for the entire hospital, particularly in the emergency departments, ICU, sterilization department, operating theatres, etc.	Generator capacity is500 KVA and 320 KVA) and sanctioned load for this hospital is 930KW. Generator has capacity to meet 100% demand. Verified that generator get started as soon as mains supply foils.
59	Regular tests of generator performance are carried out in critical areas? Determine the frequency of generator performance tests that have satisfactory results.	as mains supply fails. DG set is activated only when mains fail. It should be activated even if mains is available after fix time interval, say once a week.
60	1) Maintenance of generator or UPS system is done by skilled person? 2) what is time interval between preventive maintenance	1)Yes 2) Preventive maintenance. Once in a month.
61	Is generator properly earthed? Supply cables are properly ducted? At least two 6 Kg ABC capacity fire extinguishers are placed near the DG set.	Yes. Generator is earthed by a Aluminum bus bar properly. ***6kg ABC type fire extinguisher(2 No.s) must be kept in this shed near DG Set.
	Water Supply System	
62	Water tank has permanent reserve that is sufficient to provide at least 300 liters daily per bed for 72 Hours.	At present, 80000liter capacity well for fire fighting and 75000liter capacity drinking water tank are present on the terrace

 Θ



63	Water storage tanks are protected and in secure	V-26-14
267298	locations visit the water tanks to determine the	Verified that, water storage
	safety of the installations and of the site	tanks are protected are kept in a secure place on the terrace.
64	Alternative water supply to major distribution	Other than municipal
	network, identify the agency or mechanism to	corporation's water supply,
	supply or restore water service to the hospital	there is another alternative
	should the public water system fail	source is from well resided
		in this hospital.
65	Fuel tanks have at least 5 day capacity. Fuel	Yes
	tanks and cylinders are anchored and in a	
	secured location safe location of fuel storage.	
	Verify that tanks containing combustible liquids	Yes it is on the safe distance.
	are accessible but at a safe distance from the	×
66	hospital.	
00	Sufficient medical gas storage for minimum of 15 days supply.	Yes
	Anchors for medical gas tanks, cylinders and	V
	related equipments.	Yes
	Appropriate location for storage of medical gas.	Yes
	Safety of medical gas distribution system	Yes
	(valves, pipes, connections) Protection of	Yes
	medical gas tanks and / or cylinders and related	103
	equipment.	
67	Medical equipment in operating theatres and	,
	recovery rooms:	
	Train de la companya	
	Verify that lamps, equipment for anesthesia, and	Yes
	surgical tables are operational and that table or	
	cart wheels are locked.	×
	Condition and safety of radiology and imaging	
	equipment:	
	Verify that the X-ray and imaging equipment is	V
	in good condition and is secured.	Yes
	Condition and safety of medical equipment in	Good condition
	emergency services unit	Good collation
	Condition and safety of equipment in the	
y .	safety of equipment in the	



	sterilization unit.	
68	Condition and safety of doors and entrances, Condition and safety of windows and shutters	Found in Good Condition
69	Organization of the Hospital Disaster Committee and the Emergency Operations Center. Whether Committee has been formally established to respond to major emergencies or disasters Each member is aware of his/her specific responsibilities.	Management committee is present, it's members are aware of their specific responsibilities.
70	Transport and logistics support: Confirm that the hospital has ambulances and other official vehicles.	Hospital is having Ambulance Facility
71	Food and snacks facility?	Yes
72	Solid waste management: The Hospital staff should provide the operations manual for solid waste management.	Solid waste created by hospital is handed over to Municipal Corporation regularly.

